

THIRD FLOOR PLAN – FIRE DETECTION AND ALARM SYSTEM


SCALE 3/16" = 1'-0"

NOTE:

FIRE ALARM SYSTEM SMOKE DETECTORS SHALL NOT BE INSTALLED WITHIN 3'-0" FROM AN A.H.U. AIR SUPPLY DIFFUSER OR WITHIN 1'-0" OF A LIGHT FIXTURE.

ST. TAMMANY PARISH  
ADMINISTRATION COMPLEX RENOVATIONS

520 OLD SPANISH TRAIL  
SLIDELL, LOUISIANA



OFFICE  
801 SOUTH OAK STREET  
HAMMOND, LA. 70401

MAILING  
P.O. BOX 415  
PONCHATOULA, LA. 70454

PHONE (985) 419-1040  
FAX (985) 419-1041

DESIGNED BY:  
FRED FATH

DATE:  
OCTOBER 2010

PROJ. NO.:

SCALE:  
3/16"=1'-0"