



ROOF PLAN – FIRE DETECTION AND ALARM SYSTEM

SCALE 3/16" = 1'-0"

NOTE:

FIRE ALARM SYSTEM SMOKE DETECTORS SHALL NOT BE INSTALLED WITHIN 3'-0" FROM AN A.H.U. AIR SUPPLY DIFFUSER OR WITHIN 1'-0" OF A LIGHT FIXTURE.

ST. TAMMANY PARISH
ADMINISTRATION COMPLEX RENOVATIONS

520 OLD SPANISH TRAIL
SLIDELL, LOUISIANA



OFFICE
801 SOUTH OAK STREET
HAMMOND, LA. 70401

MAILING
P.O. BOX 415
PONCHATOULA, LA. 70454

PHONE (985) 419-1040
FAX (985) 419-1041

DESIGNED BY:

FRED FATH

DATE:

OCTOBER 2010

PROJ. NO.:

SCALE:

3/16"=1'-0"