



NUMBER	LOCATION OF FAN	CFM REQUIRED	STATIC PRESSURE (INCHES WATER)	HORSEPOWER	FAN TYPE (OR EQUIV.)
2	STAIR TOWER AIR SUPPLY	1,260	0.12	0.25	HARTZELL 12" A02SH1240---STA0D3 277 V./3Ø/ 60hz /0.25hp PROPELLER FAN
2	EXECUTIVE TOILETS EXHAUST	40	0.20	0.04	BROAN QTxE60 120 V./1Ø/ 60 hz/ 3.6 W
2	6th FLOOR TOILETS EXHAUST	570	0.25	0.47	BROAN LOSONE L700L 120 V./1Ø/ 60 hz/ 313 W
2	5th FLOOR TOILETS EXHAUST	475	0.25	0.35	BROAN LOSONE L500L 120 V./1Ø/ 60 hz/ 232 W
2	4th FLOOR TOILETS EXHAUST	515	0.25	0.47	BROAN LOSONE L700L 120 V./1Ø/ 60 hz/ 313 W
2	3rd FLOOR TOILETS EXHAUST	425	0.25	0.35	BROAN LOSONE L500L 120 V./1Ø/ 60 hz/ 232 W
2	2nd FLOOR TOILETS EXHAUST	465	0.25	0.35	BROAN LOSONE L500L 120 V./1Ø/ 60 hz/ 232 W
2	1st FLOOR TOILETS EXHAUST	250	0.25	0.34	BROAN LOSONE L250L 120 V./1Ø/ 60 hz/ 252 W

NUMBER	TONS	TEMPERATURES	MAX. GPM FLOW	HEAD PRESSURE	ELECT. POWER	MCA	MODEL		
REQUIRED	MAX. RECD	^o FARENHEIT IN OUT		FEET H ₂ O	VOLT/PHASE/HERTZ	AMPS	(OR EQUAL)		
2	80	50 40	193	50	460/3/60	168.6	CARRIER 30RB080		
							AMBIENT TEMP 95° F		
							INCL. CHILLED WATER PUMP		
							REFRIGERANT R410A		
							A/C COIL CONDENSER COILS		

