



ROTOLO CONSULTANTS INCORPORATED

894 ROBERT BLVD. SLIDELL, LA 70458 (985) 643-2427 FAX (985) 643-2691

## REQUEST FOR VARIANCE LETTER

Project Name: Lake Wood Manor Apartments Pool Renovation  
Location: Jefferson Parish, Louisiana  
Date: 6-5-2015

Dr. Jimmy Guidry,  
*State Health Officer*

Please consider this letter an official request for variance for two underwater seat benches as shown per plans being submitted. Both the underwater benches meet the "Underwater Seat Bench Variance Criteria" listed as part of the LAC 51 XXIV Swimming Pools, specifically the following:

- Benches are ajoined to pool depths less than 5'-0".
- The Benches do not project into swim lanes, as this is a free form pool design.
- The benches are designed at 18" of water depth.
- The benches are designed at 18" in width.
- The benches will have a leading tile band to be contrasting.
- The bench edges will have a 1" radius.
- Benches with associated steps will receive handrails

The project plans for Lake Wood Manor Apartments Pool Renovation are reviewed by Dammon Engineering (*state licensed engineers*) for compliancy with the LAC 51 XXIV swimming pools code.

Michael Rotolo,  
Rotolo Consultants Inc.

