

SPLIT SYSTEM DX SCHEDULE - BOYET JUNIOR HIGH GYM

SPLIT SYSTEM DX SCHEDULE - BOYET JUNIOR HIGH GYM																											
AIR HANDLER														CONDENSER										REMARKS			
TAG	AREA SERVED	Make/Model	Model / Size	Nominal Tonnage	Total CFM	OA CFM	External SP ("WC)	FAN		COOLING		FILTERS	HEAT		POWER			MCA	MOP	TAG	TRANE HEAT PUMP MODEL NO.	POWER			MCA	MOP	
								QTY	HP	TMBH	SMBH		KW	STEPS	VAC	PH	Hz					VAC	PH				Hz
AHU-3	Boys Locker Room	Trane	4TEE3F64	5	1980	340	0.4	1	1	60	41	MERV-6	7.2	1	208	1	60	52	60	CJ-3	4TTR4060	208	1	60	34	60	1, 2, 3, 4
AHU-4	Girls Locker Room	Trane	4TEE3F64	5	1980	300	0.4	1	1	60	41	MERV-6	7.2	1	208	1	60	52	60	CJ-4	4TTR4060	208	1	60	34	60	1, 2, 3, 4

NOTES:

- 1 Cooling capacities to be rated in accordance with AHR1 standard 210/290 for ASHRAE standard design weather conditions in New Orleans, LA.
- 3 Install units in accordance with manufacturer's recommendations.
- 2 Provide controls per attached drawings and specifications
- 4 Provide new filters after commissioning and final acceptance.