

## DAVID@DAMMONENGINEERING.COM

---

**From:** Curtis Craig <borderlineugly@gmail.com>  
**Sent:** Monday, March 20, 2023 9:14 PM  
**To:** DAVID@dammonengineering.com  
**Subject:** Boyett Jr. High construction estimate

David,

The estimate I reviewed showed the units being installed at grade level and does not include the structural steel support frames. This is going to require a detailed steel frame drawing along with about one week of crane time to do the installation. This includes both units. Overhead work is quite expensive and requires an extra level of caution to not damage the existing roof system. You might want to include some kind of protection for the traffic on the roofs. Fabrication of the steel is not a big deal but coating of the steel needs to be addressed. Epoxy coating or some other (primer, 2 top coats) industrial coatings system needs to be included. Don't forget to include the roof flashings.

### Bill for Engineering Services

Site investigation	3hrs
Design of support steel	24hrs
Estimate review	1hr
	28 hrs @ \$80.00 = \$2240

Curtis