

**Table 407
Minimum Plumbing Fixtures¹**

Building or Occupancy²	Occupant Content²	Water Closets³			Lavatories⁴			Bathtubs, Showers and Miscellaneous Fixtures		
Dwelling or Apt. House	Not Applicable	1 for each dwelling or dwelling unit			1 for each dwelling or dwelling unit			Washing machine connection per unit ⁵ . Bathtub or shower - one per dwelling or dwelling unit. Kitchen sink - one per dwelling or dwelling unit.		
Schools: Licensed Pre-School, Day Care or Nursery	Maximum Daily Attendance	Children (total)			Fixtures			To be provided in the same proportions as the number of water closets required		
		Age 0-4 years						Kitchen:		
		1-20			1	1 in each food preparation and utensil washing area located to permit convenient use by all food and utensil handlers.			7-15 3 compartment sink (or approved domestic or commercial dishwashing machine and a 2 compartment sink) ¹⁸	
		21-40			2	Caring for Infants: 1 in or adjacent to each diaper changing area but never to be located in a food preparation/storage or utensil washing area.			16-up 3 compartment sink (dishwashing machine, if provided, must be a commercial type) ¹⁸	
		41-80			3					
		For each additional 40 children over 80, add			1				One laundry tray, service sink, or curbed cleaning facility with floor drain on premises for cleaning of mops/mop water disposal. Caring for Infants: One extra laundry tray, service sink, or similar fixture is required to clean and sanitize toilet training potties immediately after each use. Such fixture shall be dedicated solely for this purpose and shall not be in the food preparation/storage, utensil washing, or dining areas.	
		Age 5 years and above								
			Male	Female						
		1-40	1	1						
		41-80	1	2						
81-120	2	3								
121-160	2	4								
For each additional 40 females over 160, add				1						
For each additional 80 males over 160, add			1							
Schools: Elementary & Secondary	Maximum Daily Attendance	Persons (total)			Persons (total)			One drinking fountain for each 3 classrooms, but not less than one each floor		
		1-50	2	2	1-120	1	1			
		51-100	3	3	121-240	2	2			
		101-150	4	4	For each additional 120 persons over 240, add			1	1	
		151-200	5	5						
		For each additional 50 persons over 200, add			1	1				
Office ⁶ and Public Buildings ²²	100 sq ft per person	Persons (total)			Persons (total)			Drinking Fountains		
		1-15	1	1	1-15	1	1	1-100	1	
		16-35	1	2	16-35	1	2	101-250	2	
		36-55	2	2	36-60	2	2	251-500	3	
		56-100	2	3	61-125	2	3	No less than one fixture each floor subject to access.		
		101-150	3	4	For each additional 120 persons over 125, add			1	1.5 ⁷	
		For each additional 100 persons over 150, add			1	1.5 ⁷				

(continued)