

**Table 407
Minimum Plumbing Fixtures¹**

Building or Occupancy ²	Occupant Content ²	Water Closets ³			Lavatories ⁴			Bathtubs, Showers and Miscellaneous Fixtures	
		Persons (total)	Male	Female	Persons (total)	Male	Female	Drinking Fountains ^{2,4} Persons	Fixtures
Clubs, Lounges, and Restaurants/ Food Service Establishments with Club, or Lounge ^{17,23}	30 sq ft per person	1-25	1	1	1-150	1	1	1-100	1
		26-50	2	2	151-200	2	2	101-250	2
		51-100	3	3	201-400	3	3	251-500	3
		101-300	4	4	For each additional 200 persons over 400, add				
		For each additional 200 persons over 300, add	1	2	Bar:	1	1		
				Bar:			3 compartment sink (dishwashing machine, if provided, must be a commercial type) ¹⁸		
				1 in each drink preparation and utensil washing area located to permit convenient use by all drink and utensil handlers.			Other Fixtures:		
							One laundry tray, service sink, or curbed cleaning facility with floor drain on premises for cleaning of mops/mop water disposal.		
Do it yourself Laundries ⁶	50 sq ft per person	Persons (total)	Male	Female	Persons (total)	Male	Female	One drinking fountain and one service sink.	
		1-50	1	1	1-100	1	1		
		51-100	1	2	101-200	2	2		
Beauty Shops, Barber Shops, Nail Salons, and Tanning Facilities ⁶	50 sq ft per person	Persons (total)	Male	Female	Persons (total)	Male	Female	One drinking fountain and one service sink or other utility sink.	
		1-35	1	1	1-75	1	1		
		36-75	1	2					
Heavy manufacturing, ¹⁰ warehouses ¹¹ foundries, and similar establishments ^{12,13}	Occupant content per shift, substantiated by owner. Also see 407.3.2	Persons (total)	Male	Female	Persons (total)	Male ¹⁴	Female ¹⁴	One drinking fountain for each 75 persons. One shower for each 15 persons exposed to excessive heat or to skin contamination with poisonous, infectious, or irritating material.	
		1-10	1	1	1-15	1	1		
		11-25	2	1	16-35	2	1		
		26-50	3	1	36-60	3	1		
		51-75	4	1	61-90	4	1		
		76-100	5	1	91-125	5	1		
For each additional 60 persons over 100, add	1	0.1 ⁷	For each additional 100 persons over 125, add	1	0.1 ⁷				
Light Mfg. ¹⁰ Light Warehousing ¹¹ and workshops, etc. ^{12,13}	Occupant content per shift, substantiated by owner. Also see 407.3.2	Persons (total)	Male	Female	Persons (total)	Male ¹⁴	Female ¹⁴	One drinking fountain for each 75 persons. One shower for each 15 persons exposed to excessive heat or to skin contamination with poisonous, infectious, or irritating material.	
		1-25	1	1	1-35	1	1		
		26-75	2	2	36-100	2	2		
		76-100	3	3	101-200	3	3		
		For each additional 60 persons over 100, add	1	1	For each additional 100 persons over 200, add	1	1		

(continued)