

Automatic Sprinkler System Modifications REQUEST FOR EXEMPTION

PLEASE PRINT CLEARLY OR TYPE INFORMATION

LOUISIANA DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
OFFICE OF STATE FIRE MARSHAL
8181 INDEPENDENCE BOULEVARD
BATON ROUGE, LOUISIANA 70806
PHONE (225) 925-4920 FAX (225) 925-4414
WEB SITE: www.dps.state.la.us/sfm

REVIEW FEE
\$20.00

DATE OF APPLICATION 4-1-10
STATE FIRE MARSHAL ARCHITECTURAL REVIEW NUMBER PO 367234

SHREVEPORT 888-634-7682
 NEW ORLEANS 888-634-7689
 LAFAYETTE 800-554-0006
 BATON ROUGE 800-256-5452
 HEALTH CARE
 CONTACT THE INDICATED DISTRICT OFFICE FOR FINAL INSPECTION:

PROJECT TITLE (Name of Business) NORTHSHORE CHURCH		PROJECT FLOOR 1	
NAME OF BUILDING/SHOPPING CENTER		TOTAL NO FLOORS IN BUILDING 1	
PHYSICAL LOCATION OF PROJECT Inside City Limits <input checked="" type="checkbox"/> Outside City Limits <input type="checkbox"/>	ADDRESS (Street/Suite) 300 KENSINGTON AVENUE CITY (In or Near) SLIDELL, LA	EXEMPTION RESUBMITTAL? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO PREVIOUS REVIEW NUMBER :	ZIP CODE 70458 PARISH ST. TAMMANY

PROFESSIONAL OF RECORD (P.O.R.) (If none, then MUST be Owner)

NAME DAMMON ENGINEERING INC.	PHONE (985) 649-5832
MAILING ADDRESS (Street/P.O. Box) 1095 FLORIDA AVENUE	FAX (985) 641-5950
CITY SLIDELL	STATE LA ZIP CODE 70458
P.O.R. LICENSE NO 0001350	EMAIL ADDRESS DAMMONENG@BELLSOUTH.NET

SPRINKLER SYSTEM INFORMATION

OCCUPANCY CLASS (NFPA 101 Chapter) 12	HAZARD CLASS (PER NFPA 13) LIGHT	PUMP INFORMATION PRESSURE (psi) 45	PLACARD INFORMATION GPM/SF OVER
SYSTEM TYPE <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY	DESIGN TYPE <input checked="" type="checkbox"/> HYDRAULIC <input type="checkbox"/> PIPE SCHEDULE	MAIN REDUC. VLV. SET N/A psi PRESS REDUC. VLV. SET N/A psi	FLOW (gpm) 1000
WATER SOURCE <input checked="" type="checkbox"/> MUNICIPAL <input type="checkbox"/> PRIVATE	WATER SUPPLY DATA (psi) 62	STATIC (psi) 62	RESIDUAL (psi) 56
TOTAL NUMBER OF EXEMPTION SPRINKLERS 10	AREA COVERED BY THIS EXEMPTION (sf) 8,498	FLOW (gpm) 1061	TEST DATE 1/8/10
COST OF WORK DO BE DONE \$ 15,458		PLACARD INFORMATION SF, WITH DEMAND OF PSI AT MISSING GPM AT:	

DESCRIPTION OF WORK

RELOCATE SIX SPRINKLER HEADS, ADD TWO SPRINKLER HEADS AND PLUG TWO SPRINKLER HEADS

SPRINKLER MFGR. TYCO	MODEL TY3211	TYPE TY-L	TEMPERATURE: 165°	ORIFICE SIZE: 1/2"
EFFECT ON SYSTEM NONE ANTICIPATED				

SPRINKLER SYSTEM CONTRACTOR / ENGINEER / DESIGNER (not the POR)

NAME NANCY HINGLE <i>Nancy Hingle 4/1/10</i>	EMPLOYEE STATE LICENSE NO. E4187
FIRM NAME SIMPLEXGRINNELL	FIRM MAILING ADDRESS 5800 JEFFERSON HWY., STE. A
CONTACT NAME NANCY HINGLE	HARAHAN, LA 70123
FIRM LICENSE NUMBER F767	PHONE NO (504) 736-0104 FAX NO (504) 736-9292
EMAIL ADDRESS NHINGLE@SIMPLEXGRINNELL.COM	

FOR FIRE MARSHAL USE ONLY	DATE RECEIVED 4/1/10	PROJECT NUMBER 379186	REVIEW ARCHITECT BURCH
<input checked="" type="checkbox"/> Accepted	Comments accepted under Burch replaces 378280 4/1/10		
<input type="checkbox"/> Denied			

CC: Applicant Sprinkler Contractor SFM District Fire Prevention Bureau SFM Health Care High Rise File Reading File

sprkmods.cdf - 4/1/2003