

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

NEW CONSTRUCTION

ROBERT WILTSE
DAMMON-ENGINEERING INC
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0410783
LIVING THE WORD INTERNATIONAL (NEW
CHURCH)
2528 OLD SPANISH TRAIL
SLIDELL, LA 70458

NFPA 101, 2009
IBC, 2009 (CHAPTERS 9 & 10)

ASSEMBLY OVER 300 OCCUPANTS
BUSINESS
MERCANTILE CLASS C

Dear Applicant:

This is to advise that we have reviewed the drawings and specifications for the subject proposed construction and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

1. **Scope of Work: This review is for the construction of a NEW 20,000 SQUARE FOOT LIVING WORD INTERNATIONAL CHURCH.**
2. **LAC 55:V:307 Periodic observation of construction shall be made by a licensed ARCHITECT or civil engineer. The enclosed Certificate of Completion containing the signature(s) of the responsible design professional(s) shall be presented to the Inspector at time of final inspection for occupancy.**
3. **A REVIEW FOR COMPLIANCE WITH THE FIRE PROTECTION AND EGRESS REQUIREMENTS OF CHAPTERS 9 AND 10 OF THE INTERNATIONAL BUILDING CODE IS INCLUDED IN THIS REVIEW. Review for compliance with all other requirements of the LOUISIANA STATE UNIFORM CONSTRUCTION CODE, in accordance with Act 12 of the 2005 First Extraordinary Session of the Louisiana Legislature, IS NOT INCLUDED IN THIS REVIEW. Contact the building official of the applicable political subdivision to coordinate compliance with these requirements. LRS 40:1730.23 mandates the enforcement of building codes by municipalities and parishes in Louisiana, as described by LRS 40:1730.28.**

Note: In accordance with LRS 40:1730.39.A, this office may establish contract agreements with municipalities and parishes in order to provide uniform construction code enforcement on their behalf, as provided in LRS 40:1730.24. Please visit our web site at <http://www.dps.state.la.us/sfm/index.htm> for a current list of jurisdictions requesting plan review by this office, a fee schedule, and a checklist of information required for review.

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

FIRE ALARM SYSTEM

ROBERT WILTSE
DAMMON ENGINEERING INC
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0415129
LIVING THE WORD INTERNATIONAL
CHURCH
2528 OLD SPANISH TRAIL
SLIDELL, LA 70458

NFPA 101, 2009
IBC, 2009 (CHAPTERS 9 & 10)

ASSEMBLY OVER 300 OCCUPANTS
BUSINESS
MERCANTILE CLASS C

Dear Applicant:

The fire alarm system for the above referenced project has been reviewed for compliance with NFPA 72 as shown on the drawings.

This is to advise that we have reviewed the drawings and specifications for the proposed Fire Alarm system and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.

1. **101:12.3.4.3.7 and IBC 907.2.1.1 The Fire Alarm System shall automatically provide evacuation or relocation instructions via an approved system. Horns and bells are not allowed in assembly occupancies.**
2. **101:12.3.4.3.6 and IBC 907.2.1.1 The announcement shall be made via an approved voice communications or public address system in accordance with 9.6.3.9.2.**
3. **101:12.3.4.3.3 Occupant notification shall be by means of voice announcements, either live or prerecorded, initiated by the person in the constantly attended receiving station. Horns and bells are not allowed in assembly occupancies.**
4. **101:12.3.4.3 The required fire alarm system shall activate an audible and visible alarm in a constantly attended receiving station within the building when occupied for purposes of initiating emergency action.**
5. **101:9.6.3.4 Positive alarm sequence shall comply with NFPA 72:24.4.1.3.**

May 11, 2012
P0415129 - PAGE 1

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

FIRE SUPPRESSION SYSTEM

ROBERT WILTSE
DAMMON ENGINEERING INC
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0416469
LIVING THE WORD CHURCH
2528 OLD SPANISH TRAIL
SLIDELL, LA 70458

NFPA 101, 2009
IBC, 2009 (CHAPTERS 9 & 10)


ASSEMBLY OVER 300 OCCUPANTS
BUSINESS
MERCANTILE CLASS C

Dear Applicant:

Please be advised that we have made a general review of the drawings, calculations, and equipment data for the proposed Fire Suppression System, based on the submittal package received for the above referenced project. This review is governed by the Official Manual of the Office of State Fire Marshal, which contains the adopted laws, codes, rules, and regulations of this office. This review, in no way, shall permit and/or authorize any omissions or deviations from the specific requirements of the Official Manual. Requirements cited in this review do not relieve the licensed fire suppression system designer and the Professional Of Record, when required by LA RS 37, from complying with all the requirements contained in the Official Manual. Subsequent to our general review of the submittal package, we have determined that the drawings, calculations, and equipment data appear to satisfactorily comply with the adopted laws, codes, rules and regulations of the State Fire Marshal, subject to the following requirements and review qualifications:

1. **This fire protection system review is limited to the original plan review scope as per State Fire Marshal letter P0416469/410783.**
2. **This review applies to the riser(s), piping lay-out and sprinkler head locations, for compliance with NFPA 13, 2007 Edition as shown on the drawings for the above referenced project. NFPA 25, Standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems is a requirement of this office and shall be adhered to.**
3. **The project encompasses the new construction of the Living The Word Church in Slidell, La. The structure is protected by a wet system which covers a total floor area of 20, 000 sqft.**

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.



STATE OF LOUISIANA
DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
OFFICE OF STATE FIRE MARSHAL



CERTIFICATE OF COMPLETION

DATE: _____

SFM PROJECT PO 410783 SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____
 SFM PROJECT PO 415129 SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____
 SFM PROJECT PO 416469 SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____
 SFM PROJECT PO _____ SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____

Please list all projects pertaining to the currently scheduled reviews of the building System type refers to Architectural, Fire Alarm, Kitchen Hood/Wet Chemical Suppression, Fire Suppression, or Storage Tank.

To arrange for inspection of the project, please contact the district office two (2) to three (3) weeks in advance. To verify inspection district and phone number please refer to the "cc" list on the last page of the State Fire Marshal review letter. The plans stamped reviewed by this office must be available on job site at time of inspection. This Certificate Of Completion must be provided to the inspecting deputy at final inspection.

This is to certify the below project

PROJECT TITLE FROM APPLICATION		
PROJECT ADDRESS		
CITY	STATE	ZIP CODE

was periodically observed by me, by my consultants, and/or by others in my employ during construction and, to the best of my knowledge, information and belief, has been completed in accordance with the safety provisions which were shown in the plans and specifications previously reviewed by the Fire Marshal.

UNDER PENALTY OF LAW FOR FALSE STATEMENTS, I (NAME OF ARCHITECT/ENGINEER IF REQUIRED, OTHERWISE OWNER)

PRINT NAME _____ SIGNATURE _____

ARCHITECT/ CIVIL ENGINEER LICENSE NUMBER _____

CERTIFY ALL STATEMENTS CONTAINED HEREIN ARE, TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF, TRUE AND CORRECT.

LAC 55:V:307 OBSERVATION OF CONSTRUCTION

A. For a structure which by law may only be constructed with plans prepared and certified by a licensed architect or civil engineer, it shall be the duty of the owner of such a structure to provide for periodic observation of the construction of the structure to determine if the work is proceeding in accordance with the plans and specifications as approved by the fire marshal. The observations shall be performed by a registered architect or a registered civil engineer.

B. Upon completion of such work, where the law requires the owner to engage an architect or registered civil engineer the owner shall furnish to the fire marshal a certificate signed by a registered architect or registered civil engineer stating that the periodic observations have been made and that to the best of the architect's or engineer's knowledge, information and belief, the work was completed in accordance with those fire safety standards and regulations stipulated in the plans and specifications previously approved by the fire marshal. When the owner has not engaged an architect or registered civil engineer, and the same is not required by law, the owner must submit the certificate of completion when appropriate, but always under his signature.

C. Occupancy of a structure, watercraft or movable prior to furnishing a certificate to the fire marshal as required under this regulation is expressly forbidden by the fire marshal, unless and until a satisfactory inspection has been made by the fire marshal or his certified representative.

D. In order to comply with the requirements of §307.B, the owner must submit to the fire marshal the following certificate completed by the architect, civil engineer, or, if neither is required by law, the owner.