

10484

Automatic Sprinkler System Modifications REQUEST FOR EXEMPTION

PLEASE PRINT CLEARLY OR TYPE INFORMATION

DATE OF APPLICATION	9-2-09
STATE FIRE MARSHAL ARCHITECTURAL REVIEW NUMBER	PO 319467

LOUISIANA DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
 OFFICE OF STATE FIRE MARSHAL
 8181 INDEPENDENCE BOULEVARD
 BATON ROUGE, LOUISIANA 70806
 PHONE (225) 925-4920 FAX (225) 925-4414
 WEB SITE: www.dps.state.la.us/sfm

REVIEW FEE
\$20.00

SHREVEPORT 888-634-7682
 NEW ORLEANS 888-634-7689
 LAFAYETTE 800-554-0006
 BATON ROUGE 800-256-5452

PROJECT TITLE (Name of Business)	Club E Youth Center	PROJECT FLOOR	1
NAME OF BUILDING/SHOPPING CENTER		TOTAL NO FLOORS IN BUILDING	1
PHYSICAL LOCATION OF PROJECT	ADDRESS (Street/Suite)	EXEMPTION RESUBMITTAL? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	PREVIOUS REVIEW NUMBER:
Inside City Limits <input checked="" type="checkbox"/>	1321 Gause Blvd. Ste 3		
Outside City Limits <input type="checkbox"/>	CITY (In or Near)	ZIP CODE	PARISH
	Slidell	70458	St Tammany

PROFESSIONAL OF RECORD (P.O.R.) (if none, then MUST be Owner)

NAME	Dammon Engineering	PHONE	(985) 649-5832
MAILING ADDRESS (Street/P.O. Box)	1095 Florida Ave	FAX	(985) 641-5950
CITY	Slidell	STATE	LA
		ZIP CODE	70458
P.O.R. LICENSE NO	4030	EMAIL ADDRESS	

SPRINKLER SYSTEM INFORMATION

OCCUPANCY CLASS (NFPA 101 Chapter)	Assembly	HAZARD CLASS (PER NFPA 13)	Light Hazard	PUMP INFORMATION	PLACARD INFORMATION
SYSTEM TYPE	WET DRY	DESIGN TYPE	HYDRAULIC PIPE SCHEDULE	PRESSURE (psi)	GPM/6' OVER
WATER SOURCE	MUNICIPAL PRIVATE	WATER SUPPLY DATA	STATIC (psi)	FLOW (gpm)	SE, WITH DEMAND OF
			66	1090	PSI AT
TOTAL NUMBER OF EXEMPTION SPRINKLERS	50	AREA COVERED BY THIS EXEMPTION (sq ft)	RESIDUAL (psi)	TEST DATE	GPM AT:
			64	1/6/09	

DESCRIPTION OF WORK

Add 2 and relocate 4 heads. Raise 44 pendant heads to upright heads for ceiling being removed.

SPRINKLER MFRG.	Viking	MODEL	M	TYPE	Upr QR	TEMPERATURE	155°	ORIFICE SIZE	1/2"
EFFECT ON SYSTEM	None.								

SPRINKLER SYSTEM CONTRACTOR / ENGINEER / DESIGNER (not the POR)

NAME	Stephanie Enclade	EMPLOYEE STATE LICENSE NO.	E 6181
FIRM NAME	Jefferson Sprinkler Inc.	FIRM MAILING ADDRESS	PO Box 129 Gretna, LA 70054
CONTACT NAME	Raymond Strohmeier, Jr.	FIRM LICENSE NUMBER	F 760
		PHONE NO	(504) 393-7699
		FAX NO	(504) 367-0216
		EMAIL ADDRESS	raymonds@jeffersonsprinkler.com

FOR FIRE MARSHAL USE ONLY	DATE RECEIVED	370070	REVIEW ARCHITECT
<input checked="" type="checkbox"/> Accepted	9-2-09		Burch
<input type="checkbox"/> Denied	accepted under Burch 9/3/09		

CC: Applicant Sprinkler Contractor SFM District Fire Prevention Bureau SFM Health Care High Rise File Reading File

spkmods.ccr --4/1/2003

CONTACT THE INDICATED DISTRICT OFFICE FOR FINAL INSPECTION: