

**Subject:** Re: Club E Youth Center P0#319467  
**To:** "CHUCK DAMMON" <chuckdammon@yahoo.com>  
**CC:** dborn@cityofslidell.org, egiroir@cityofslidell.org, kbaker@cityofslidell.org  
**From:** Jim.Waite@dps.la.gov  
**Date:** Thu, 18 Jan 2007 13:38:33 -0600

Chuck,

That comment was cited in error and does not apply to this project, Please disregard.

The electrical submittal on this project appears to comply.

Jim Waite  
Staff Architect - Plan Review  
LA Office of the State Fire Marshal  
(225) 925-4920

To: CHUCK DAMMON  
<chuckdammon@yahoo.com>  
[Jim.Waite@dps.la.gov](mailto:Jim.Waite@dps.la.gov)  
01/18/2007 01:35 PM  
Subject: Re: Club E Youth Center  
P0#319467

Jim,  
Per our phone conversation today I have verified that the electrical panel dwg that we submitted to your office for review shows a 400 amp panel and not a 600 amp panel as described in your review letter for the IBC. Please email me back for approval.

Thank you for all your help.  
Chuck Dammon 01/18/07

[Jim.Waite@dps.la.gov](mailto:Jim.Waite@dps.la.gov) wrote:

Chuck,

This was done and released on the 12th, last week. you should have something in the mail today.

Just in case here's a copy of the IBC review letter.

(See attached file: P0319467 - Club E Youth Centerr.doc)

Jim Waite  
Staff Architect - Plan Review  
LA Office of the State Fire Marshal  
(225) 925-4920

CHUCK DAMMON  
o.com> To  
[Jim.waite@dps.la.gov](mailto:Jim.waite@dps.la.gov)  
01/18/2007 09:34 cc  
AM  
Subject  
Club E Youth Center P0#319467

Hey Jim,  
I was wondering if you had a chance to look at Club E Youth Center P0#319467 for review.

Please call or email me with any questions you may have for this project.

#985-649-5832

Thanks  
Chuck Dammon

Never Miss an Email  
Stay connected with Yahoo! Mail on your mobile. Get started!

Don't pick lemons.  
See all the new 2007 cars at Yahoo! Autos.