

hp color LaserJet 9500mfp series



Fax Call Report

1

Dammon Engineering
985-641-5950
2008-Jan-23 12:00 PM

Job	Date/Time	Type	Identification	Duration	Pages	Result
36	2008-Jan-23 11:59 AM	Send	6497679	1:09	0	No answer (0)

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

January 23, 2008

K. B. Kaufmann & Co., Inc.
1019 Old Spanish Trail
Slidell, LA 70458
Attn: Dave Kaufmann
Via fax: 985.649.7679

Re: Kaufmann Home Office
UL Assembly

Dear Dave,

As per your recent request, I have researched and attached several UL rated assemblies for an 8" single wythe CMU wall to substitute for the 4" & 6" double wythe wall shown on the plans. Let me know which assembly (U904 - U907) you may prefer. The main difference is in the classification of the concrete block, and I do not know what your supplier is providing for you.

I will include this revision in a response package I am preparing for the Fire Marshall review architect.

Call me if you have any questions.

Sincerely,

Robert Wiltse
Dammon Engineering, Inc.