

GA FILE NO. WP 1072 GENERIC

ONE LAYER 5/8" TYPE X GYPSUM WALLBOARD OR GYPSUM VENEER BASE APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 3-5/8" STEEL STUDS 24" O.C. WITH 1" TYPE S DRYPWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. AT FLOOR AND CEILING RUNNERS AND INTERMEDIATE STUDS.

JOINTS STAGGERED 24" ON EACH SIDE AND ON OPPOSITE SIDES. SOUND TESTED WITH 3-1/2" GLASS FIBER FRICTION FIT IN STUD SPACE. (NON-LOAD BEARING)


1 HOUR FIRE 45 TO 49 STC SOUND



THICKNESS: APPROX. WEIGHT: 6 PSF
FIRE TEST: 4-7/8"

SEE WP 1200 (FM WP 45, G-19-G8), OSU 1-1770, 8-6-1; ULC 7917A84, 791500, 791497, 8-1-2-8-1, ULC DESIGN W4 15) NRCC 81 G-NV, 2-3-81

FLOOR PLAN
SCALE: 3/16" = 1'



NOTE: ALL DIMENSIONS ARE TO FACE OF STUD, EXCEPT COLUMN GRID LINES, UNLESS OTHERWISE NOTED.

GREEN STATEFARM
RETAIL COMPLEX
381-391 GAUSE
BLVD., WEST
SLIDELL, LA

FLOOR
PLAN

REV:

SCALE: AS NOTED


JOB#: 2057

DATE: 06-23-10

SHEET 8

A-1

OF 19



DAMMON ENGINEERING, INC.

CHIEF ENGINEER
EMMETT DAMMON, P.E.
CHIEF ARCHITECT
ROBERT WILTSE

1095 FLORIDA AVENUE
SLIDELL, LA, 70458
OFFICE: 985-649-5832
FAX: 985-641-5950

WEBSITE:
WWW.DAMMONENGINEERING.COM

EMAIL:
DAMMONENR@BELLSouth.NET

ARCHITECTURE
ENGINEERING
STUDIES
PLANNING
INVESTIGATION
EXPERT WITNESS