



### ELECTRICAL LEGEND

SYMB.	DESCRIPTION	NOTE	SYMB.	DESCRIPTION	NOTE
⊕	STANDARD 120V DUPLEX RECEPT. @ 1' Ø - AFF (UNLESS NOTED)		⊕	ELECTRIC PANEL	
⊕	DEDICATED RECEPTACLE	SEE SHEET E-2 FOR PANEL SCHEDULE	⊕	POWER DISCONNECT	
⊕	SEE PNL SCHEDULE FOR CIRCUIT SIZE		⊕	DUAL CAT 5 JACK WITH FACEPLATE NETWORKING CONNECTION	
⊕	GF1 120V DUPLEX RECEPTACLE @ 1' Ø A.F.F. (UNLESS NOTED)		⊕	SMOKE DETECTOR, U.L. LISTED, PHOTOELECTRIC, DIGITAL, INTELLIGENT	
⊕	WEATHER PROOF 120V DUPLEX RECEPT. @ 30' A.F.F. (UNLESS NOTED)		⊕	SWITCH	
⊕	STANDARD 120V DUPLEX RECEPT. @ COUNTER HEIGHT				
⊕	4' LONG, 4 LAMP FLUORESCENT FIXTURE HUNG FROM ROOF ABOVE				

**EQUIPMENT NOTES:**  
 1. RUN WIREMOLD ON EXISTING CMU WALLS TO OUTLET LOCATIONS SHOWN.

PNL-1

NO.	TYPE	DESCRIPTION	AMPS	VOLTS	PHASE	LOCATION	THRU	NO.
1	RECEPTACLE	120V	15	1	1	OFFICE	4	2
2	RECEPTACLE	120V	15	1	1	OFFICE	4	3
3	RECEPTACLE	120V	15	1	1	OFFICE	4	4
4	RECEPTACLE	120V	15	1	1	OFFICE	4	5
5	RECEPTACLE	120V	15	1	1	OFFICE	4	6
6	RECEPTACLE	120V	15	1	1	OFFICE	4	7
7	RECEPTACLE	120V	15	1	1	OFFICE	4	8
8	RECEPTACLE	120V	15	1	1	OFFICE	4	9
9	RECEPTACLE	120V	15	1	1	OFFICE	4	10
10	RECEPTACLE	120V	15	1	1	OFFICE	4	11
11	RECEPTACLE	120V	15	1	1	OFFICE	4	12
12	RECEPTACLE	120V	15	1	1	OFFICE	4	13
13	RECEPTACLE	120V	15	1	1	OFFICE	4	14
14	RECEPTACLE	120V	15	1	1	OFFICE	4	15
15	RECEPTACLE	120V	15	1	1	OFFICE	4	16
16	RECEPTACLE	120V	15	1	1	OFFICE	4	17
17	RECEPTACLE	120V	15	1	1	OFFICE	4	18
18	RECEPTACLE	120V	15	1	1	OFFICE	4	19
19	RECEPTACLE	120V	15	1	1	OFFICE	4	20
20	RECEPTACLE	120V	15	1	1	OFFICE	4	21
21	RECEPTACLE	120V	15	1	1	OFFICE	4	22
22	RECEPTACLE	120V	15	1	1	OFFICE	4	23
23	RECEPTACLE	120V	15	1	1	OFFICE	4	24
24	RECEPTACLE	120V	15	1	1	OFFICE	4	25
25	RECEPTACLE	120V	15	1	1	OFFICE	4	26
26	RECEPTACLE	120V	15	1	1	OFFICE	4	27
27	RECEPTACLE	120V	15	1	1	OFFICE	4	28
28	RECEPTACLE	120V	15	1	1	OFFICE	4	29
29	RECEPTACLE	120V	15	1	1	OFFICE	4	30

### ELECTRICAL NOTES

- ALL WORK SHALL CONFORM TO THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE, THE GOVERNING ELECTRICAL CODE AND ALL OTHER INSPECTION DEPARTMENTS HAVING JURISDICTION. OBTAIN CERTIFICATES OR APPROVAL WHERE REQUIRED.
- ALL MATERIALS FURNISHED SHALL BE NEW AND SHALL BE U.L. LISTED.
- THE DRAWINGS INDICATE SIZE AND GENERAL LOCATION OF WORK. SCALE DIMENSIONS SHALL NOT BE USED. THE EXACT LOCATION AND LOCATION OF ALL LIGHTING FIXTURES, RECEPTACLES AND TELEPHONE OUTLETS, ETC. SHALL BE DETERMINED BY ACTUAL CONDITIONS IN THE FIELD.
- PRIOR TO BIDDING, CONTRACTOR SHALL VISIT THE JOB SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS.
- ELECTRICAL CONTRACTOR SHALL COORDINATE HIS WORK WITH OTHER TRADES AND WITH OTHER CONTRACTORS WHOSE WORK MAY AFFECT THIS INSTALLATION.
- ELECTRICAL CONTRACTOR SHALL COORDINATE INCOMING ELECTRICAL SERVICE WITH UTILITY COMPANY AND INCLUDE IN HIS BID ALL CHARGES AND FEES INCURRED IN MODIFICATIONS.
- WHERE MORE THAN ONE SWITCH OCCURS IN THE SAME LOCATION, THEY SHALL BE INSTALLED IN A GANG TYPE BOX UNDER ONE COVER PLATE.
- ELECTRICAL CONTRACTOR SHALL COORDINATE THE TELEPHONE INSTALLATION WITH THE TELEPHONE COMPANY AND THE GENERAL CONTRACTOR.
- ELECTRICAL CONTRACTOR, BEFORE INSTALLING ANY OF THE WORK, SHALL SEE THAT IT DOES NOT INTERFERE WITH CLEARANCES REQUIRED FOR FINISHED COLUMNS, HUNG CEILINGS, PLASTER, PARTITIONS, WALLS, ETC. AS SHOWN IN THE ARCHITECTURAL DRAWINGS AND DETAILS. IF ANY WORK IS INSTALLED AND IT LATER DEVELOPS THAT SUCH CHANGES IN THE WORK AS DIRECTED BY THE ARCHITECT, AT HIS OWN EXPENSE, SHALL MAKE SUCH CHANGES IN THE WORK AS DIRECTED BY THE ARCHITECT, AS WELL AS TO PERMIT THE INSTALLATION OF THE ARCHITECTURAL WORK AS SHOWN ON THE PLANS AND DETAILS.
- PERFORM TEST REQUIRED BY THE OWNER OR THE ENGINEER IN CONNECTION WITH THE OPERATION OF THE ELECTRICAL SYSTEM IN THE BUILDING.
- ALL TESTS SHALL BE MADE IN ACCORDANCE WITH THE LATEST STANDARD OF THE IEEE AND THE NATIONAL ELECTRICAL CODE.
- MINIMUM CONDUCTOR SIZE SHALL BE #12. 600V INSULATION. MINIMUM SIZE CONDUIT SHALL BE 3/4" EMT FOR INTERIOR USE, AND 3/4" RIGID ALUMINUM OR PVC SCHEDULE 80 FOR EXTERIOR USE. USE TYPE NMVC CABLE COPPER, FOR LIGHTS AND RECEPTACLE CIRCUITS. EXTERIOR FITTINGS SHALL BE CAST BOXES AND COVERS. INTERIOR FITTINGS SHALL BE CAST WHERE EXPOSED ON WALLS. STAMPED BOXES MAY BE USED ABOVE CEILINGS IN AIR CONDITIONED SPACES, WHERE LAY IN FIXTURES ARE IN USE. USE 1/4" 2 ALLOWED FOR 6" WIDTH.
- CONTRACTOR SHALL INSTALL WIRING AND OTHER CIRCUIT COMPONENTS TO MATCH EQUIPMENT ACTUALLY INSTALLED.
- INSTALL GROUND FAULT RECEPTACLES AT RECEPTACLE LOCATIONS WITHIN 5' OF SINKS OR LAVATORIES, AND AT EXTERIOR LOCATIONS. EXTERIOR RECEPTACLES SHALL ALSO BE WATERPROOF.
- BONDING AND GROUNDING SHALL BE IN ACCORDANCE WITH NFPA 70:250-63, NFPA 250-23, 250-71 & 250-72.
- GROUND NEUTRAL IN ACCORDANCE WITH NFPA 70:250-23b.
- FUSES SHALL BE 11T CLASS K5, 250 VOLT, 200,000 AMP INTERRUPTING CAP.
- PROVIDE SERVICES OF A FIRE/SMOKE DETECTION AND ALARM COMPANY TO DESIGN AND INSTALL ALARM SYSTEM TO MEET REQUIREMENTS OF THE STATE FIRE MARSHAL.
- EXTERIOR LIGHTING SHALL BE SHADDED OR INWARDLY DIRECTED IN SUCH A MANNER SO THAT NO DIRECT LIGHTING, OR GLARE IS CAST BEYOND THE PROPERTY LINE. THE INTENSITY OF SUCH LIGHTING SHALL NOT EXCEED ONE FOOT CANDLE AS MEASURED AT THE ADJUTING PROPERTY LINE.
- ALL ELECTRICAL, MECHANICAL AND PLUMBING PENETRATING FIRE PARTITIONS SHALL BE FIRE CAULKED. PENETRATIONS THROUGH RATED CONSTRUCTION SHALL BE SEALED WITH A MATERIAL CAPABLE OF PREVENTING THE PASSAGE OF FLAMES AND HOT GASES WHEN TESTED IN ACCORDANCE WITH ASTM-E814.)

ELECTRICAL PLAN  
 SCALE: 3/8"=1'

### LIGHTING FIXTURE SCHEDULE

SYMB.	DESCRIPTION	QTY
⊕	PENDANT LIGHT	13
⊕	WALL MOUNT. PARAGON EYES / DENT W/ BATT. BACKUP	2
⊕	CEILING MOUNTED INCANDESCENT	2
⊕	EXTERIOR WALL MOUNTED INCANDESCENT	1

**DAMMON ENGINEERING, INC.**  
 CHIEF ENGINEER  
 ENWETT  
 DAMMON, P.E.  
 CHIEF ARCHITECT  
 ROBERT  
 WILTSE

1095 FLORIDA AVENUE  
 SLIDELL, LA, 70458  
 OFFICE: 985-649-5632  
 FAX: 985-641-5950

WEBSITE:  
 WWW.DAMMONENGINEERING.COM

EMAIL:  
 DAMMONENR@BELLFLOW.NET

ARCHITECTURE  
 ENGINEERING  
 STUDIES  
 PLANNING  
 INVESTIGATION  
 EXPERT WITNESSES

TENANT BUILD-OUT

CHAMPAGNE BUILDING LLC  
 2242 CAREY ST.  
 SLIDELL, LA 70458

ELECTRICAL PLAN

SCALE: AS NOTED  
 JOB#: 2086  
 DATE: 11-08-10  
 SHEET 5

REV: