



- NOTES:**
1. TO DRIVEN GROUND ROD SYSTEM & COLD WATER PIPE. BOND IAW NEC ART. 250.
 2. 2 EA. (2-500 KCMIL, 1-#2 STINGER, 1-500 KCMIL N, 3" C).
 3. 2 EA. (2-500 KCMIL, 1-#2 STINGER, 1-500 KCMIL N, 1-3/0 GND, 4" C).
 4. NEW WIREWAY (SIZE PER CONNECTOR BLOCK MANUFACTURER) POLARIS CONNECTOR BLOCK IFLD 500-6 PER PHASE, OR EQUAL.
 5. 2 EA. (2-4/0, 1-4/0 N, 1-#3 GND, 2" C).
 6. 1 EA. (2-#2, 1-#2 N, 1-#8 GND, 1-2" C).
 7. 1 EA. (2-4/0, 1-4/0 STINGER, 1-4/0 N, 1-#6 GND, 2-2" C).

NOTE: 911 ADDRESS SHALL BE A MINIMUM OF 3" LETTERING MARKED ON METER ENCLOSURE

RISER DIAGRAM
N.T.S.