



- NOTES:**
- * CONCRETE STRENGTH IS 4,800 PSI
 - * @ 28 DAYS
 - * STRUCTURE JOINTS TO BE SEALED WITH FLAT BUTYL SEALANT (CONSEAL)
 - * STANDARD PUMP CONFIGURATION SHOWN
 - * 60 GPM AT 15'TDH



28021 Coker-Vail Road
 Phone (225) 567 - 2700
 Holden, LA
 Fax (225) 567 - 3089
 www.gaineysconcrete.com

WET WELL & VALVE PIT
 REGION 2
 2/12/10

6564C