

## CONSTRUCTION

Amend	Section 312.10.2, Testing.	Reduced pressure principle, double-check, pressure vacuum breaker, reduced pressure detector fire protection, double check detector fire protection, and spill-resistant vacuum breaker backflow preventer assemblies shall be tested at the time of installation, immediately after repairs or relocation and at least annually. The testing procedure shall be performed in accordance with one of the following standards: ASSE 5013, ASSE 5015, ASSE 5020, ASSE 5047, ASSE 5048, ASSE 5052, ASSE 5056, CSA B64.10.1, USC's FCCC and HR's "Manual of Cross-Connection Control", or UFL's TREEO's "Backflow Prevention—Theory and Practice". Any backflow preventer which is found to be defective shall be repaired. Test gauges shall comply with ASSE 1064.
Adopt	Section 312.10.3, Owner Responsibilities.	The owner of the backflow prevention assemblies shall comply with the following:
Adopt		1. It shall be the duty of the owner of the backflow prevention assembly to see that these tests are made in a timely manner in accord with the frequency of field testing specified in 312.10.2 of this code.
Adopt		2. The owner shall notify the building official, and/or water supplier (for those devices associated with containment) in advance when the tests are to be undertaken so that the building official and/or water supplier may witness the tests if so desired.
Adopt		3. Upon completion, the owner shall provide records of such tests, repairs, overhauls, or replacements to the building official or water supplier (for those devices associated with containment). In addition, all records shall be kept by the owner of the backflow prevention device or method for at least five years and, upon specific request, shall be made available to the building official or water supplier.
Adopt		4. All tests, repairs, overhauls or replacements shall be at the expense of the owner of the backflow preventer.
Amend	Chapter 4	
Amend	Section 403.1, Fixture Calculations.	
Amend	Table 403.1	
Amend	Footnote (f.)	The required number and type of plumbing fixtures for outdoor public swimming pools shall be in accordance with the following:
Adopt	Item (1.)	Facilities that have less than 7500 gross square feet (697 m <sup>2</sup> ) of water area available for bather access shall have not less than one water closet for males, one urinal for males, one lavatory for males, one shower for males, two water closets for females, one lavatory for females and one shower for females.
Adopt	Item (2)	Facilities that have 7500 gross square feet (697 m <sup>2</sup> ) or more of water area available for bather access shall have not less than 0.7 water closet for males, one urinal for males, 0.85 lavatory for males, one shower for males, two water closets for females, one lavatory for females and one shower for females for every 7500 square feet (697 m <sup>2</sup> ) or portion thereof. Where the result of the fixture calculation is a portion of a whole number, the result shall be rounded up to the nearest whole number.
Amend	Footnote (e.)	For business and mercantile classifications with an occupant load of 25 or fewer, service sinks shall not be required except for Day Care Centers and Food (consumable) establishments such as restaurants, bar/lounge etc.
Amend	Section 403.1.1.	
Amend	Exceptions	
Amend	Item (2.)	Where multiple-user facilities are designed to serve all genders, the minimum fixture count shall be calculated 100 percent, based on total occupant load. In such multiple-user facilities, each fixture type shall be in accordance with ICC A117.1 and each urinal that is provided shall be located in a room, created by walls from floor to ceiling, with a solid door.
Adopt	Item (4)	Child day care occupancies shall not be required to have bathtubs or showers.
Amend	Section 403.2, Separate facilities.	
Amend	Exception	
Amend	Item (6.)	Separate facilities shall not be required where rooms, created by walls from floor to ceiling, with a solid door, having both water closets and lavatory fixtures are designed for use by both sexes and privacy for water closets is provided in accordance with Section 405.3.4. Urinals shall be located in a room, created by walls from floor to ceiling, with a solid door.
Adopt	Item (7.)	Separate facilities shall not be required for existing tenant spaces under 1800 sq. ft. where the occupancy classification is either B or M.
Amend	Section 403.3 Employee and public toilet facilities.	
Amend	Exception	
	Item 2	Structures and tenant spaces intended for quick transactions, including takeout, pickup and drop-off, having a public access area less than or equal to 300 square feet (28 m <sup>2</sup> ) and shall be prohibited from containing public tables or chairs on the premises.
Amend	Section 403.3.3, Location of Toilet Facilities in Occupancies other than Malls and Educational Buildings.	In occupancies other than covered and open mall buildings, and educational buildings, the required public and employee toilet facilities shall be located not more than one story above or below the space required to be provided with toilet facilities, and the path of travel to such facilities shall not exceed a distance of 500 feet (152 m).
Amend	Exceptions	
Adopt	Item (3.)	In mini-storage facilities where the access is for outdoor use only a restroom is not required.
Adopt	Item (4.)	A single user toilet facility shall be installed in climate controlled mini-storage facilities and mini-storage facilities for outdoor use only which contain an onsite office.