


DIRECTORY		WATTS LOAD		CKT NO.	AMPS		AMPS	CKT NO.	WATTS LOAD		DIRECTORY	
		L1	L2						L1	L2		
Cooler 3	1575		1	20		20	2	1575		Cooler 4		
		1575							1575			
Register	500		3	20		20	4	500		Snack		
Register		500	5	20		20	6		1000	Cooler 3rd From Left		
Freezer	1000					20	10	1000		Pepsi Mountain Dew		
		1000	7	30		20	12		1000	Starbucks		
SUBTOTAL		3075	3075					3075	3575		SUBTOTAL	
VOLTAGE: 240/120 PHASE: 1 WIRE: 3						TOTAL WATTS, L1		6150	PANEL NO.		P2	
MAIN BREAKER: NO						TOTAL WATTS, L2		6650				
MAIN BUS: 100 AMP NTL BUS: YES GND BUS: YES						TOTAL WATTS		12800	LOCATION		STORAGE ROOM	
MANUFACTURER: MURRAY			MODEL: LC		MFG DATE:2002		MOUNTING: SURFACE					
NOTES: FED FROM PANEL M1, BREAKER 23/25												