



GA FILE NO. WP 1072 GENERIC

ONE LAYER 5/8" TYPE X GYPSUM WALLBOARD OR GYPSUM VENEER
 BASE APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF
 3-5/8" STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS
 8" O.C. AT VERTICAL JOINTS AND 12" O.C. AT FLOOR AND CEILING
 RUNNERS AND INTERMEDIATE STUDS.

JOINTS STAGGERED 24" ON EACH SIDE AND ON OPPOSITE SIDES.
 SOUND TESTED WITH 3-1/2" GLASS FIBER FRICTION FIT IN STUD
 SPACE. (NON-LOAD BEARING)

1 HOUR FIRE 45 TO 49 STC SOUND

THICKNESS: 4-7/8"

APPROX. WEIGHT: 6 PSF

FIRE TEST: SEE WP 1200 (RM WP-45, 6-19-60);
 OSU 15-1770, 8-6-1; ULC 791424, 791500,
 791497, 8-12-81; ULC DESIGN WA151
 NRCC 816-NV, 2-3-81

SOUND TEST: 1 HR SEPARATION DETAIL

FLOOR PLAN
 SCALE: 3/16" = 1'

NOTE: ALL DIMENSIONS ARE TO FACE
 OF GYP. BD. EXCEPT COLUMN GRID LINES,
 UNLESS OTHERWISE NOTED.

Not there
 817 - 886-1112

REVISIONS	DATE	DESCRIPTION

**GREEN-STATEFARM RETAIL
 COMPLEX-TENANT BUILDOUT**

331-391 GALEE BOULEVARD, WEST
 SUDELL, LOUISIANA

JOB No: DATE: 12-11-2012

DRAWN BY: JTL CHECKED BY:

DAMMON
 ENGINEERING INC
 Architects & Engineers

CHIEF ENGINEER: EMMETT DAMMON, P.E.
 CHIEF ARCHITECT: ROBERT WILTSE

354 OLD SPANISH TRAIL
 SUDELL, LA 70450

dammoneng@earthlink.net
 dammoneng@earthlink.net
 PHONE: 985-649-5832
 FAX: 985-641-5950

REVISED
 LATEST
 FLOOR PLAN
 SCHEME - C

SHEET No: **A-1**