



FOUNDATION NOTES

1. ALL DIMENSIONS ARE EDGE OF CONCRETE (EOC) TO EDGE OF CONCRETE (EOC) UNLESS NOTED OTHERWISE
2. CONCRETE MIX SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3000 PSI AT 28 DAYS. CONCRETE MIX SHALL BE IN ACCORDANCE WITH ACI 318.
3. ALL CONVENTIONAL REINFORCING STEEL SHALL MEET ASTM-A615 (GRADE 60).
4. ALL REINFORCING STEEL AND MESH SHALL BE SECURELY SUPPORTED TO PREVENT BOTH VERTICAL AND HORIZONTAL MOVEMENT DURING CONCRETE PLACEMENT.
5. THE CONTRACTOR SHALL VERIFY ALL DROPS, OFFSETS, BRICK LEDGES, DIMENSIONS AND CONFIGURATIONS.
6. GRADE BEAM DIMENSIONS MAY VARY BY -5% - +20%.
7. CONTRACTOR SHALL FILL UNDER HOISE TO PREVENT WATER BUILDUP TO ASSURE NO WATER IS REMAINING AND SHALL REMAIN DRY.
8. FILL SHALL BE 40% CLAY AND 60% SANDY MIXTURE PLACED IN 6" LIFTS AND COMPACTED TO A MINIMUM OF 95% STANDARD PROCTOR.

DAMMON
ENGINEERING, INC.

554 Old Spanish Trail
Slidell, LA 70458
PH: 985.649.5832

www.dammonengineering.com
info@dammonengineering.com
Fax: 985.641.5950

REVISIONS		
#	DESCRIPTION	DATE

CITIS

1045 WOOD VIEW
SLIDELL, LOUISIANA 70458

JOB No: 2317 DATE: 11-15-17

DRAWN BY: CKD CHECKED BY: BAM

The above drawings and specifications, together with all agreements, specifications, conditions and terms of contract, shall govern the construction of the work herein. It is the responsibility of the contractor to obtain all necessary permits and to comply with all applicable laws, codes and regulations. The contractor shall be responsible for the accuracy of the information provided to others, or used in connection with any work or project other than the specific project for which this has been prepared and approved without written consent of Dammon Engineering. Please contact with those drawings or specifications shall constitute an acknowledgment of the contractor's responsibility for the accuracy of the information provided.

1 HOUSE PIER / FOUNDATION PLAN
SCALE: 1/4" = 1'-0"
FOUNDATION

SHEET TITLE:
HOUSE PILING AND
FOUNDATION
PLAN

DRAWING NUMBER:
5101

SHEET NO.: 1 of 4