



ST. TAMMANY PARISH
FACILITIES MANAGEMENT
P. O. BOX 628
COVINGTON, LA 70434
PHONE: (985) 898-2792
FAX: (985) 898-3073

Kevin Davis
Parish President

June 16, 2010

City of Slidell
Department of Building Safety
P.O Box 828
Slidell, LA 70459

To Whom It May Concern:

During the meeting held at the Towers Bldg at 520 Old Spanish Trail the City Mechanical inspector expressed concern about the ability to maintain the VAV units located within the office area spaces. He stated that it is not a code issue or violation; however that future maintenance would be difficult.

The Parish is aware of the situation and has addressed this concern with our HVAC maintenance contractor. We appreciate the City's concern and relieve them from any future consequents regarding this matter.

If you have any questions you can reach me at 985-898-2792 or email me at davidk@stpgov.org.

Thank you,

David Koppenol
Asst. Director of Facilities Management

From: David Koppenol (davidk@stpgov.org)
To: wwalker@cityofslidell.org;
Date: Tue, July 27, 2010 1:43:35 PM
Cc: excelconsulting@charter.net; chuckdammon@yahoo.com; brucec@stpgov.org;
Subject: Old Towers Bldg. 520 OS trail

Mr. Walker

The Parish is aware that maintenance or removal of the coils will be difficult in the mechanical rooms. Also the VAV's above the ceiling will be difficult to maintain.

Please accept this Email as a written acknowledgement to your concerns.

Thank you
David Koppenol