

From: Linda.Burch@dps.la.gov (Linda.Burch@dps.la.gov)
To: chuckdammon@yahoo.com;
Date: Tue, July 20, 2010 7:01:35 AM
Cc:
Subject: Re: Renovate Slidell Towers project, Fire Pump location

Solution as indicated below is acceptable.

thanks,

Linda Burch
Architect Supervisor
Louisiana State Fire Marshal

ph 1-225-925-4920
ph 1-800-256-5452
fx 1-225-925-4414

email: linda.burch@dps.la.gov
Louisiana State Fire Marshal web address: www.lasfm.org

CHUCK DAMMON <chuckdammon@yahoo.com>

07/19/2010 05:46 PM

To linda burch <linda.burch@dps.la.gov>

cc dammon email <dammoneng@bellsouth.net>

Subject Renovate Slidell Towers project, Fire Pump location

Hello Mrs. Burch, The local Slidell Fire Prevention (Mike Thiel) called me and said he had spoken to you earlier about this project for the Slidell Towers project review # 320959 and sprinkler review # review # 348487. This building was built in the earlier 60's and is being renovated due to hurricane hurricane Katrina.

He was asking about the location of the fire pump located on the mezzanine floor in the rear of the the building and due to the nature of the project it is being put back to original. It is currently located located and installed per the sprinkler company's submitted and approved plans. It is surrounded by by rated wall construction and on that floor is some electrical equipment for other potable water pumps pumps and a small a/c return for that area in question. It will have a fire damper in the return air and air and smoke detector in the a/c along with an approved fire alarm system and a fully sprinkled building. He is asking to get your concurrence on this location. Please see the attached pdf for clarification.

Please call or write me with any questions you may have.

*Thanks and have a great day!
Chuck Dammon*