

LEGEND

- EXH - EXHAUST FAN
- TS - FAN TEMPERATURE SWITCH
- CWS - CHILLED WATER SUPPLY
- CWR - CHILLED WATER RETURN
- T - THERMOSTAT (SET NEAR ELEV. CONTROLS)

NOTE

1. SEE DWG. M-9 "CHILLED WATER RISER DIAGRAM" FOR PIPE SIZES.
2. REPLACE EXHAUST FAN AND LOUVERS IN EAST WALL OF PENTHOUSE.

Install THRU WALL 1 1/2 TON A/C
DRAIN TO ROOF

18" DIA. VENT PIPE (EXISTING)

SEE ELEVATIONS A-8, A-9 AND A-11 FOR CLARIFICATION

OUTSIDE FRESH AIR INTAKE 24" DIRECT DRIVE FAN WITH FILTER

4" DIA. SCH. 40 PIPE (EXISTING COOLING TOWER LINES TO BE REMOVED)

make sure this is shown on demog & erase from this sheet


note on Arch slot to cut opening for thru wall unit.

ROOF MECHANICAL PLAN
ST. TAMMANY PARISH ADMIN. COMPLEX
520 OLD SPANISH TRAIL
SLIDELL, LOUISIANA

DAMMON ENGINEERING, INC.
1095 FLORIDA AVENUE 985-649-5832 SLIDELL, LA. 70458
DAMMONENGINEERING.COM

SCALE: AS NOTED
FILE:
JOB NO. 1729
DATE: 1-8-07
SHEET
M-7
OF *med 4-11*

ROOF MECHANICAL PLAN
SCALE: 3/16" = 1'-0"



REVISED: 04/09/07ab
REVISED: 03/07/07ab
REVISED: 1/29/07