


***SOV RIVERINE AND COMBATANT
CRAFT OPERATIONS FACILITY***

*Located at
John C. Stennis Space Center
Hancock County Mississippi*

***BDLG. 2440 / 2441
MASONRY DESIGN
CALCULATIONS***


April 30, 2009


Prepared by:
Dammon Engineering
1095 Florida Avenue
Slidell, La. 70458
985-649-5832
dammonengineering.com



VICINITY MAP

N. T. S.





WALL #1 ELEMENTS


STENNIS RIVERINE DESIGN OF REINFORCED CMU NONLOADBEARING WALL FOR FLEXURE BLDG 2441 — WALL #1 ELEMENT A

MATERIALS:

| | |
|---------------|--------------------|
| UNIT STRENGTH | 4050 psi |
| MORTAR | TYPE N |
| f'_m | 2500 psi |
| E_m | 2.25×10^6 |
| n | 12.89 |
| REINFORCEMENT | GRADE 60 |

LOADING:

WIND 130 MPH = 43.26 psf
NEGLECT SELF WEIGHT



REACTIONS:

$$R_{WB} = \text{REACTION @ WIND BEAM} = \frac{(43.3 \cdot (21.3')^2)}{2} = 615 \text{ plf}$$

$$R_{FL} = \text{REACTION @ FLOOR} = 43.3 \cdot \left(\frac{(19.7')^2}{2} - \frac{(1.6')^2}{2} \right) = 425 \text{ plf}$$

$$x = \frac{425}{43.3} = 9.8'$$

$$M = 425 \text{ plf} \cdot \left(\frac{9.8'}{2} \right) = 2085 \text{ ft-lb./ft.}$$

ESTIMATE REINFORCEMENTS:

TRY 8" CMU, ASSUME STEEL @ MID DEPTH

$$d = \frac{7.625''}{2} = 3.8''$$

$$A_s = \frac{M}{F_s j d} = \frac{2085 \text{ ft-lb} \cdot 12}{24000 \text{ psi} \cdot 0.9 \cdot 3.8} = 0.3 \text{ in}^2$$

USE 1/3 ALLOWABLE SAFETY FACTOR

$$A_s = \frac{2085 \text{ ft-lb} \cdot 12}{24000 \text{ psi} \cdot 0.9 \cdot 1.33 \cdot 3.8} = 0.2 \text{ in}^2$$

DESIGN STRENGTH

USING 24" WIDE STRIP DESIGN MOMENT = 2085 ft-lb · 2 = 4170 ft-lb.

$$p = \frac{A_s}{b \cdot d} = \frac{0.20 \text{ in}^2}{24 \cdot 3.8} = 0.002$$

$$pn = 0.002 \cdot 15.26 = 0.03$$

$$K^2 + 2pnK - 2pn = 0$$

$$K^2 + 0.06K - 0.06 = 0$$

$$j = 1 - \frac{K}{3} = 0.928$$

$$K = \frac{-0.06 \pm \sqrt{(0.06)^2 - 4(1)(-0.06)}}{2}$$

$$K = \frac{-0.06 \pm 0.19}{2} = 0.215"$$

ALLOWABLE CAPACITY IN TENSION

TRY #4 @ 12" O.C

$$M_t = A_s j d F_s = 0.4 \text{ in}^2 \cdot 0.9 \cdot 3.8" \cdot 24000 \text{ psi} \cdot \frac{1.33}{12} = 3640 \text{ ft-lb/ft.}$$

3640 < 4170 ft-lb/ft. DOES NOT WORK

TRY #5 @ 8" O.C.

$$M_t = 0.62 \text{ in}^2 \cdot 0.9 \cdot 3.8" \cdot 24000 \text{ psi} \cdot \frac{1.33}{12} = 5640 \text{ ft-lb/ft.}$$

5640 > 4170 ft-lb/ft. ∴ OK

ALLOWABLE CAPACITY IN COMPRESSION

$$F_b = \frac{1}{3} f'_m \cdot 1.33 = \frac{1}{3} (1500) \cdot 1.33 = 665 \text{ psi}$$

$$M_m = \frac{bd^2}{2} \cdot K \cdot j \cdot F_b = \frac{24" \cdot 3.8^2}{2} (0.215)(0.928) \frac{665 \text{ psi}}{12} = 1916 \text{ ft-lb}$$

1916 < 4170 ft-lb/ft DOES NOT WORK

ASSUME NEW f'_m


ESTIMATE REQ'D STRENGTH: $\frac{4170}{1916} \cdot 1500 \text{ psi} = 3265 \text{ psi}$ UNIT STRENGTH

NEW $f'_m = 2500 \text{ psi}$ - TYPE N MORTAR ⇒ 4,050 psi UNIT STRENGTH

$$F_b = 1795 \text{ psi}$$

$$M_m = 5170 \text{ ft-lb/ft} \quad \therefore \text{OK}$$

USE #5 @ 8" O.C. w/ 8" CMU (2500 psi) TYPE N MORTAR



WALL #1 ELEMENT A DETAIL
 N.T.S.

STENNIS RIVERINE


DESIGN OF REINFORCED CMU NONLOADBEARING WALL FOR FLEXURE
BLDG 2441 ELEMENT B (DESIGN FOR 26' x 16' OPENING)

MATERIALS:

| | |
|---------------|------------------------|
| UNIT STRENGTH | 4050 psi |
| UNITAR | TYPE N |
| f'_m | 2500 psi |
| E_m | 2.25×10^6 psi |
| n | 12.89 |
| REINFORCEMENT | GRADE 60 |

LOADING:


WIND 130 MPH = 43.26 psf
NEGLECT SELF WEIGHT



$$R = \frac{(16 \cdot 26 \cdot 43.3)}{4}$$

$$R = 4500 \text{ lbs}$$

REACTIONS @ LINTEL AND FLOOR FROM DOOR



$$R_{LIN} = \left(\frac{4500 \text{ lbs} \cdot 16'}{16'} \right) = 4500 \text{ lbs.} = 846 \text{ plf}$$

$$R_{FL} = \left(\frac{4500 \text{ lbs} \cdot 0'}{16'} \right) + 4500 \text{ lbs} = 4500 \text{ lbs.}$$

TOTAL = 9000 lbs.


ACTUAL: $[43.3 \text{ psf} \cdot (13' \cdot 16') = 9000]$

MAXIMUM MOMENT = $0 \text{ lbs} \cdot 16' = 0 \text{ ft-lb/ft}$

∴ OK

$$\text{WIND LOAD} = W = \frac{(26' \cdot 43.3 \text{ psf})}{2} = 563 \text{ plf}$$

REACTIONS @ WIND BEAM AND LINTEL FROM AREA ABOVE DOOR:



$$R_{WB} = \left(\frac{43.3 \cdot (5.3)^2 / 2'}{3.7'} \right) = 164.4 \text{ plf} (13') = 2136 \text{ lbs}$$

$$R_{LIN} = \left[43.3 \left(\frac{3.7^2}{2} - \frac{16^2}{2} \right) \right] / 3.7' = 65.1 \text{ plf} (13') = 847 \text{ lbs.}$$

TOTAL = 2983 lbs

$$x = \frac{65.1}{43.3} = 1.5'$$

ACTUAL = $[43.3 \text{ psf} (5.3' \cdot 13') = 2983]$

∴ OK

$$\text{MAX MOMENT} = (164.4 - 65.1) \left(\frac{1.5}{2} \right) = 74.8 \text{ ft-lb/ft}$$

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

MOMENT @ HEAD LOCATION FROM UNIFORM WIND ON WALL ELEM. B

$$\text{MAX MOMENT} = 425 \text{ plf} \cdot 21.3' - 43.3 \text{ psf} \left(\frac{16^2}{2} \right) = 1260 \text{ ft.-lb./ft.}$$

DESIGN MOMENT

ASSUME 32" JAMB

$$\begin{aligned} \text{MAX MOMENT} &= (74.8 \text{ ft.-lb./ft} \cdot 13') + (1260 \text{ ft.-lb./ft} \cdot 2.67') \\ &= (9724 \text{ ft.-lb.} + 3364 \text{ ft.-lb.}) = 13,088 \text{ ft.-lb.} \end{aligned}$$

ESTIMATE REINFORCEMENT:

8" CMU ASSUME $J=0.9$ FOR ESTIMATE $d=3.8"$

$$A_s = \frac{M}{F_s J d} = \frac{13088 \text{ ft-lb} \cdot 12 \text{ in/ft}}{24000 \text{ psi} \cdot 0.9 \cdot 1.33 \cdot 3.8"} = 1.4 \text{ in}^2/\text{ft.}$$

TRY (8) #4 REBAR PER FOOT

ALLOWABLE CAPACITY IN TENSION

$$M_t = A_s \cdot j \cdot d \cdot F_s = 1.6 \text{ in}^2 \cdot 0.9 \cdot 3.8" \cdot 24000 \text{ psi} \cdot \frac{1.33}{12} = 14555 \text{ ft-lb.}$$

$M_t > \text{REQ. } M: 13,088 \text{ ft-lb.} \therefore \text{OK}$

ALLOWABLE CAPACITY IN COMPRESSION

$$p = \frac{(1.6)^2}{32 \text{ in} \cdot 3.8"} = 0.02 \quad n_p = 12.89 \cdot 0.02 = 0.2578$$

$$K = \frac{-0.5 \pm \sqrt{0.5^2 - 4 \cdot 1 \cdot (-0.5)}}{2}$$


$$j = \left(1 - \frac{K}{3}\right) = \left(1 - \frac{0.5}{3}\right) = 0.83$$

$$K = \frac{-0.5 \pm 1.5}{2} = 0.5$$


$$M_m = \frac{b d^2}{2} \cdot K \cdot j \cdot F_b = \frac{32 \text{ in} \cdot 3.8^2}{2} (0.5)(0.83) \frac{1795 \text{ psi}}{12} = 14342 \text{ ft-lb.}$$

$$F_b = \frac{1}{3}(4050) \cdot 1.33 = 1795 \text{ psi}$$

$M_m > \text{REQ } M: 13,088 \text{ ft-lb.} \therefore \text{OK}$



USE (8) #4 REBAR PER FOOT AS SHOWN ABOVE.



WALL #1 ELEMENT B DETAIL
N.T.S.


STENNIS RIVERINE DESIGN OF REINFORCED CMU NONLOADBEARING WALL FOR FLEXURE BLDG 2441 — WALL #1 ELEMENT C

MATERIALS

UNIT STRENGTH 4050 psi
MORTAR TYPE N
 f'_m 2500 psi
 E_m 2.25×10^6
 n 12.89
REINFORCEMENT GRADE 60

LOADING:


WIND 130 MPH = 43.26 psf
NEGLECT SELF WEIGHT



$$R = \frac{(16 \cdot 12 \cdot 43.3 \text{ psf})}{4}$$

$$R = 2080 \text{ lbs.}$$

REACTIONS @ UNTEL AND FLOOR FROM DOOR:



$$R_{WB} = \frac{2080 \text{ lbs} \cdot 16'}{19.7'} = 1690 \text{ lbs.}$$

$$R_{FL} = \frac{2080 \text{ lbs} \cdot 3.7'}{19.7'} + 2080 \text{ lbs.} = 2470 \text{ lbs.}$$

$$\left. \begin{array}{l} R_{WB} \\ R_{FL} \end{array} \right\} \text{TOTAL} = 4160 \text{ lbs.}$$


$$[\text{ACTUAL} = 43.3 \cdot (16 \cdot 12) / 2 = 4157]$$

∴ O.K.

$$\text{MAX MOMENT} = 780 \text{ lbs} \cdot 16' = 12480 \text{ ft-lb}$$

$$\text{WIND LOAD} = \left(\frac{12' \cdot 43.3 \text{ psf}}{2} \right) = 260 \text{ plf}$$

REACTIONS @ WIND BEAM AND FLOOR FROM AREA ABOVE DOOR:



$$R_{WB} = \frac{260 \text{ plf} \cdot 5.3' \cdot 18.65'}{19.7'} = 1305 \text{ lbs.}$$

$$R_{FL} = 260 \text{ plf} \cdot \left(\frac{5.3^2}{2} - \frac{1.6^2}{2} \right) = 170 \text{ lbs}$$

$$x = \frac{65.1}{43.3} = 1.5'$$

$$\text{MOMENT} = 170 \text{ lbs} \cdot 16' = 2720 \text{ ft-lb.}$$

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

MOMENT @ HEAD LOCATION FROM UNIFORM WIND ON WALL ELEM. C:

$$\text{MAX MOMENT} = 425.4 \text{ plf} \cdot 16' - 43.3 \text{ psf} \left(\frac{16^2}{2} \right) = 1260 \text{ ft}\cdot\text{lb}/\text{ft}.$$

DESIGN MOMENT

ASSUME 32" JAMB

$$\text{MAX MOMENT} = (1260 \text{ ft}\cdot\text{lb}/\text{ft} \cdot 2.67 + 2720 \text{ ft}\cdot\text{lb} + 4680 \text{ ft}\cdot\text{lb}) = 10765 \text{ ft}\cdot\text{lb}.$$

ESTIMATE REINFORCEMENT:8" CMU ASSUME $J=0.9$ FOR ESTIMATE $d=3.8"$

$$A_s = \frac{M}{F_s j d} = \frac{10765 \text{ ft-lb} \cdot 12 \text{ in/ft}}{24000 \text{ psi} \cdot 0.9 \cdot 1.33 \cdot 3.8"} = 1.2 \text{ in}^2/\text{ft}$$

TRY (8) #4 REBAR PER FOOT

ALLOWABLE CAPACITY IN TENSION:

$$M_t = 14555 \text{ ft-lb} \quad (\text{SEE CALCULATIONS FOR WALL ELEM. B})$$


$$M_t > 10765 \text{ ft-lb} \quad \therefore \text{OK}$$

ALLOWABLE CAPACITY IN COMPRESSION

$$M_m = 14342 \text{ ft-lb} \quad (\text{SEE ELEMENT B})$$

$$M_m > 10765 \text{ ft-lb} \quad \therefore \text{OK}$$

USE (8) #4 REBAR PER FOOT AS SHOWN ON ELEM. B.



WALL #1 ELEMENT C DETAIL
N.T.S.



S TENNIS RIVERINE
DESIGN OF REINFORCED CMU NON-LOADBEARING WALL
FOR FLEXURE BLDG 2441 WALL # 2

MATERIALS:

UNIT STRENGTH 4050 psi
MORTAR TYPE N
 f'_m 2500 psi
 E_m 2.25×10^6
 n 12.89
REINFORCEMENT GRADE 60

LOADING:

WIND 130 MPH = 43.26 psf
NEGLECT SELF WEIGHT



REACTIONS:

$$R_{WB} = \left(\frac{43.26 \text{ psf} \times (30.5)^2}{2} \right) \frac{1}{19.7} = 1,021.4 \text{ PIF}$$

$$R_{FN} = 43.26 \text{ psf} \left(\frac{(19.7)^2}{2} - \frac{(10.8)^2}{2} \right) \frac{1}{19.7} = 298.0 \text{ PIF}$$

$$x = \frac{298 \text{ PIF}}{43.26 \text{ psf}} = 6.89 \text{ FT}$$

BLDG 2441 WALL #2 Cont.

ESTIMATE REINFORCEMENT

8" CMU, ASSUME STEEL MID-DEPTH $d = \frac{7.625''}{2} = 3.8''$

$$A_s = \frac{M}{F_s j d} = \frac{(1026.6 \text{ ft}\cdot\text{lb})(12 \text{ in}/\text{ft})}{(24,000 \text{ psi})(1.33)(0.9)(3.8'')} = 0.113 \text{ in}^2/\text{ft}$$

Try #5 @ 24" O.C. ($A_s = 0.31 \times \frac{12}{24} = 0.155 \text{ in}^2/\text{ft}$)

DESIGN STRENGTH

USE 2.0 FT wide STRIP

DESIGN MOMENT = $1026.6 \text{ ft}\cdot\text{lb}/\text{ft} = 2,053.2 \text{ ft}\cdot\text{lb}/\text{ft}$

$$p = \frac{A_s}{bd} = \frac{0.31 \text{ in}^2}{24 \text{ in} \times 3.8 \text{ in}} = 0.00339$$

$$np = 0.0438 \quad k^2 + 2pnk - 2pn = 0$$

$$k = 0.335 \quad j = 1 - \frac{k}{3} = 0.889$$

ALLOWABLE CAPACITY IN TENSION

#5 @ 24" O.C.

$$M_t = A_s j d F_s = 0.31 \times 0.889 \times 3.8 \times 24,000 \cdot \frac{1.33}{12} =$$

$$M_t = 2,785.7 \text{ ft}\cdot\text{lb}/\text{ft} > 2,053.2 \text{ ft}\cdot\text{lb}/\text{ft}$$

ALLOWABLE CAPACITY IN COMPRESSION


$$M_m = \left(\frac{bd^2}{2}\right) k j F_b =$$

$$F_b = \frac{1}{3} f'_m \times 1.33 = \frac{1}{3} (4,050 \text{ psi}) 1.33 = 1795 \text{ psi}$$

$$M_m = \left(\frac{24'' \times 3.8^2}{2}\right) 0.335 \times 0.889 \times \frac{1795 \text{ psi}}{12 \text{ in}/\text{ft}} = 7,719.3 \frac{\text{ft}\cdot\text{lb}}{\text{ft}}$$

USE #5 @ 24" O.C. 8" CMU TYPE N MORTAR

T.O.M. HEIGHT VARIES AT ENDWALL
 MEAN ROOF HEIGHT = 30'-6"



WALL#2 TYPICAL DETAIL
 N.T.S.

STENNIS RIVERINE DESIGN OF REINFORCED CMU NONLOADBEARING WALL FOR FLEXURE BLDG 2440 WALL #3

MATERIALS:




| | |
|---------------|--------------------|
| UNIT STRENGTH | 2150 psi |
| MORTAR | TYPE N |
| f'_m | 1500 psi |
| E_m | 2.25×10^6 |
| n | 12.89 |
| REINFORCEMENT | GRADE 60 |

LOADING:

WIND 130 mph = 43.3 psf
NEGLECT SELF WEIGHT

NOTE

CONTINUOUS LATERAL SUPPORT @ 12.0'
CONSIDER UPPER COMPONENT FOR CALCULATIONS
DUE TO HIGHER MAX MOMENT



REACTIONS:

$$R_{WB} = \left[\frac{43.3 \cdot (12')^2}{2} \right] / 10.67' = 292.2 \text{ plf}$$

$$x = \frac{230 \text{ plf}}{43.3} = 5.31'$$

$$R_{FL} = 43.3 \left[\frac{\left(\frac{10.67}{2} - \frac{1.3^2}{2} \right)}{10.67'} \right] = 230 \text{ plf}$$

$$M = 230 \text{ plf} \left(\frac{5.31'}{2} \right) = 610 \text{ ft-lb/ft}$$

ESTIMATE REINFORCEMENT:

TRY 8" CMU, STEEL @ MID DEPTH $d = 3.8"$

$$A_s = \frac{M}{F_s \cdot j \cdot d} = \frac{610 \text{ ft-lb} \cdot 12}{24000 \text{ psi} \cdot 0.9 \cdot 3.8} = 0.09 \text{ in}^2/\text{ft}$$

DESIGN STRENGTH

USING 24" WIDE STRIP

DESIGN MOMENT = $610 \text{ ft-lb} \cdot 2 = 1220 \text{ ft-lb}$.

$$p = \frac{A_s}{bd} = \frac{0.20}{24 \cdot 3.8} = 0.002$$

$$pn = 0.03$$

$$K = 0.28$$

$$j = \left(1 - \frac{K}{3}\right) = 0.91$$

ALLOWABLE CAPACITY IN TENSIONTRY #4 @ 16" o.c. $A_s = 0.15$

$$M_t = A_s j d F_s = 0.15 \text{ in}^2 (0.93)(3.8)(24000) \frac{1.33}{12} = 1410 \text{ ft-lb./ft.}$$

$$1410 > 1220 \therefore \text{OK}$$


ALLOWABLE CAPACITY IN COMPRESSION

$$F_b = 665 \text{ psi}$$

$$M_m = \frac{ba^2}{2} K j F_b = \frac{24 \cdot 3.8^2}{2} (0.28)(0.91) \left(\frac{665 \text{ psi}}{12}\right) = 2446 \text{ ft-lb.}$$

$$2446 > 1220 \therefore \text{OK}$$

USE #4 REBAR @ 16" o.c. w/ 8" CMU (1500psi) TYPE N MORTAR



WALL#3 TYPICAL DETAIL

N.T.S.


STENNIS RIVERINE
DESIGN OF REINFORCED CMU NONLOADBEARING WALL FOR FLEXURE
BLDG 2440 WALL #4

MATERIALS:

| | |
|---------------|--------------------|
| UNIT STRENGTH | 2150 psi |
| MORTAR | TYPE N |
| f'_m | 1500 psi |
| E_m | 2.25×10^6 |
| n | 12.89 |
| REINFORCEMENT | GRADE 60 |

LOADING:

WIND 130 MPH = 43.3 psf
NEGLECT SELF WEIGHT



REACTIONS:

$$R_{WB} = \left[\frac{43.3 (18.5')^2}{2} \right] / 10.67' = 695 \text{ plf}$$

$$x = \frac{106.6 \text{ ft}}{43.3} = 2.5'$$

$$R_{FL} = 43.3 \left[\frac{(10.67')^2}{2} - \frac{7.83^2}{2} \right] / 10.67' = 106.6 \text{ plf}$$

$$M = 106.6 \text{ plf} \left(\frac{2.5}{2} \right) = 133.27 \text{ ft-lb/ft}$$

ESTIMATE REINFORCEMENT:

TRY 8" CMU, STEEL @ MID DEPTH $d = 3.8"$

$$A_s = \frac{M}{F_s j d} = \frac{135 \text{ ft-lb/ft} \cdot 12}{24000 \text{ psi} (0.9) (3.8") (1.33)} = 0.02 \text{ in}^2 / \text{ft.}$$

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

DESIGN STRENGTH:

USE 24" WIDE STRIP

$$\text{DESIGN MOMENT} = 133.3 \text{ ft-lb/ft} \times 2 = 270 \text{ ft-lb}$$

$$P = 0.005 \quad \rho n = 0.06 \quad K = 0.28 \quad j = 0.98$$

ALLOWABLE CAPACITY IN TENSION

TRY #5 @ 16" O.C.

$$M_t = A_s (0.98)(3.8)(24000) \frac{1.33}{12} = 3070 \text{ ft-lb}$$

$$3070 > 270 \text{ ft-lb} \therefore \underline{\text{OK}}$$

ALLOWABLE CAPACITY IN COMPRESSION


$$F_b = \frac{1}{3}(f'_m)1.33 = \frac{1}{3}(1500)1.33 = 665 \text{ psi}$$

$$M_m = \left(\frac{24 \cdot 3.8^2}{2} \right) (0.28)(0.98) \left(\frac{665}{12} \right) 1.33 = 2635 \text{ ft-lb}$$

$$2635 > 270 \therefore \underline{\text{OK}}$$

USE #5 @ 16" O.C. 8" CMU TYPE N MORTAR

T.O.M. HEIGHT VARIES AT ENDWALL
 MEAN ROOF HEIGHT = 30'-6"



WALL#4 TYPICAL DETAIL
 N.T.S.

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

TYPICAL ANCHORAGE AND SPLICE FOR #5 REBAR

USE #5 REBAR FOR HOOK, GRADE 60

l_d = REQ'D DEVELOPMENT LENGTH

$$l_d = \frac{0.13 \cdot d_b^2 \cdot f_y \cdot \psi}{K \cdot \sqrt{f'_m}} = \frac{0.13 \cdot (0.625)^2 \cdot 60000 \cdot 1}{5 \cdot (0.625) \cdot \sqrt{2500}} = 19.5''$$

$$l_e = 13d_b = 8.125''$$

VENEER WALL CONNECTION

USE "POS-1-TIE" TAPCON SCREW FOR CMU EMBED @ 8" VERTICAL O.C. AND 16" HORIZ. O.C., MIN EMBED. LENGTH 1-3/4". USE 3/16" ϕ x 3" S.S. TRIANGLE WIRE TIES @ EA. CONNECTION. SEE ATTACHED PRODUCT SHEET.

HORIZ. JOINT REINFORCEMENT

USE HELKMANN #110085 S.S. LADDER-TYPE MASONRY WALL REINFORCEMENT @ EVERY OTHER COURSE. SEE ATTACHED PRODUCT SHEET.

TYPICAL ANCHORAGE AND SPLICE FOR #4 REBAR

USE #4 REBAR FOR HOOK, GRADE 60

$$l_d = 20.1''$$

$$l_e = 6.5''$$




1501 N. 31st Avenue
 Melrose Park, IL 60160-2911
 800 621-4140 or 708 865 2403
 FAX: 708-865-2640
 www.heckmannanchors.com
 Email: info@heckmannbuildingprods.com


ARCHITECTURAL SPECIFICATION INFORMATION

THE ORIGINAL Pos-I-Tie®

U.S. Patent# 4473984 & 4764069 Canada Patent# 1224344



Seven Barrel lengths available for Insulation/gypsum board sizes and combinations:
 1/2" & 5/8", 1", 1-1/2", 2", 2-1/2", 3", and 3-1/2"



The Pos-I-Tie® conforms with the Energy Conservation Requirements of the Massachusetts State Building Code (780 CMR 13 Envelope)


NO. 75 POS-I-TIE® ADVANTAGES

1. Pos-I-Tie® system fully complies with the ACI 530 Code. The Barrel Screw is one piece. No more plates, screws and gaskets. Installs in seconds.
2. Uses consistent screw. Screw is provided as a part of the Pos-I-Tie® System. - No inferior screws can be substituted.
3. Provides positive connections. The Barrel Section actually penetrates sheathing and makes a Positive Lateral Connection with the backup for transfer of compression and tension loads to structural backup.
4. Enables speedy cost-saving installation. Only one screw needs to be placed, rather than two screws.
5. Corrosion Resistant. Pos-I-Tie® seals the hole it makes when it seats itself in the backup. Barrel section is made of ZAMAC 3, a 92% zinc alloy. Screws are Zinc electro plated.
6. Slotted Barrel allows for differential movement due to temperature variations. Tie design provides for allowable ACI 530 code vertical adjustment.
7. Allows for use of 4' x 8' insulation sheets. The Pos-I-Tie® holds the insulation in place!

Test Data Available Upon Request

WIRE TIES

Ties are 3/16" diameter x 3", 3 1/2", 4", or 5" Long in Hotdip Galvanized, Mill Galvanized and Stainless Steel.



Special Lengths available.

(Check for local code acceptance of single wire tie.)

CMU ANCHOR TO WIND BEAM



Heckmann Building Products Inc.

1501 N. 31st Avenue

Melrose Park, IL 60160-2911

800-621-4140 or 708-865-2403 Fax: 708-865-2640

www.heckmannbuildingprods.com

SUBMITTAL SHEET: #1100 Ladder-Type Masonry Wall Reinforcement.

Manufactured from 9 Gage wire, 10' 8" long with butt-welded perpendicular cross wires welded 16" on center to avoid interference with reinforcement in block cores.

Wire is deformed for maximum bonding in mortar joints.

Packaged in 50 pc (500 lin ft) bundles


Special sizes and lengths are available.

- Reduces Cracking.
- Increases lateral flexural strength.
- Increases ductility and elasticity.

Standard Catalog Numbers

Size

| Mill Galv | Hotdip Galv | Stainless Steel | Width | Wall Size |
|-----------|-------------|-----------------|-------|-----------|
| 11006G | 11006H | 11006S | 4 | 6 |
| 11008G | 11008H | 11008S | 6 | 8 |
| 11010G | 11010H | 11010S | 8 | 10 |
| 11012G | 11012H | 11012S | 10 | 12 |



ASTM A82 cold drawn steel wire.
Tensile Strength 80,000 PSI
Yield Point 70,000 PSI minimum
Reduction of Area 30%

Finishes:

Stainless Steel:

ASTM A 580 Type 304.

Hotdip Galvanized:

ASTM A 153 Class B-2: (1.50 oz/ ft²)(0.46kg/m²)

Mill Galvanized:

Wire: ASTM A 641 (0.1 oz/ ft².)

Conforms to requirements of ASCE / ACI 530 / TMS402 Building Code requirements for masonry structures.

Approvals:

Comments: