

**Permit**

<b>Permit #:</b> LAG481115	<b>Permittee:</b> DEPT OF PUBLIC SAFETY	<b>Facility:</b> DEPT OF PUBLIC SAFETY - STATE POLICE TROOP L
<b>Major:</b> No	<b>Permittee Address:</b> 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471	<b>Facility Location:</b> 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471
<b>Permitted Feature:</b> 002 External Outfall	<b>Discharge:</b> 002-Q Exterior Vehicle & Equip. Wash, Equip. Repair Area, Shop Floor, & Dock Washdown, & Utility WashWater	

**Report Dates & Status**

<b>Monitoring Period:</b> From 07/01/21 to 09/30/21	<b>DMR Due Date:</b> 10/28/21	<b>Status:</b> NetDMR Validated
---	-------------------------------	---------------------------------

**Considerations for Form Completion**

COD limit for washwater commingled with stormwater shall be 125mg/L Daily Maximum

**Principal Executive Officer**

<b>First Name:</b>	<b>Title:</b>	<b>Telephone:</b>
<b>Last Name:</b>		

**No Data Indicator (NODI)**

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Ty	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units
00340	Oxygen demand, chem. [high level] [COD]	1 - Effluent Gross	0	--	Sample								<	12.0	<	12.0	19 - mg/L	01/90 - Quarterly	GR - GRAE
					Permit Req.								<=	200.0 MO AVG	<=	300.0 DAILY MX	19 - mg/L		
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.6			=	7.6	12 - SU	01/90 - Quarterly	GR - GRAE	
					Permit Req.					>=	6.0 INST MIN			<=	9.0 INST MAX	12 - SU			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample									<	5.0	19 - mg/L	01/90 - Quarterly	GR - GRAE	
					Permit Req.								<=	45.0 DAILY MX	19 - mg/L				
					Value NODI														
00556	Oil & Grease	1 - Effluent Gross	0	--	Sample									<	5.0	19 - mg/L	01/90 - Quarterly	GR - GRAE	
					Permit Req.								<=	15.0 DAILY MX	19 - mg/L				
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	180.0	=	180.0	07 - gal/d								01/90 - Quarterly	ES - ESTII
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	07 - gal/d									
					Value NODI														

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**  
No attachments.

**Report Last Saved By**  
DEPT OF PUBLIC SAFETY  
User: NPAC0405  
Name: Nicole Riviere  
E-Mail: nriviere@eeusa.com  
Date/Time: 2021-11-10 13:06 (Time Zone: -06:00)

**Report Last Signed By**  
User: LSP\_TROOPL  
Name: Louis Calato  
E-Mail: louis.calato@la.gov  
Date/Time: 2021-11-10 14:11 (Time Zone: -06:00)

# Submission Receipt

Submission Date: 11-10-2021

Submitter Name: Louis Calato

Submitter Telephone: (985) 893-6250