

Permit

Permit #: **LAG481115** | Permittee: DEPT OF PUBLIC SAFETY  
 Major: No | Permittee Address: 2600 N CAUSEWAY BLVD  
 MANDEVILLE, LA 70471 | Facility: DEPT OF PUBLIC SAFETY - STATE POLICE TROOP L  
 Facility Location: 2600 N CAUSEWAY BLVD  
 MANDEVILLE, LA 70471  
 Permitted Feature: 002 | Discharge: **002-Q**  
 External Outfall | Exterior Vehicle & Equip. Wash, Equip. Repair Area, Shop Floor, & Dock Washdown, & Utility WashWater

Report Dates & Status

Monitoring Period: From 07/01/22 to 09/30/22 | DMR Due Date: 10/28/22 | Status: **NetDMR Validated**

Considerations for Form Completion

COD limit for washwater commingled with stormwater shall be 125mg/L Daily Maximum

Principal Executive Officer

First Name: | Title: | Telephone: |  
 Last Name:

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Ty			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00340	Oxygen demand, chem. [high level] [COD]	1 - Effluent Gross	0	--	Sample								<	12.0	<	12.0	19 - mg/L	0	01/90 - Quarterly	GR - GRAE
					Permit Req.								<=	200.0 MO AVG	<=	300.0 DAILY MX	19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.5			=	7.5	12 - SU	0	01/90 - Quarterly	GR - GRAE	
					Permit Req.					>=	6.0 INST MIN			<=	9.0 INST MAX	12 - SU				
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample									=	9.1	19 - mg/L	0	01/90 - Quarterly	GR - GRAE	
					Permit Req.								<=	45.0 DAILY MX	19 - mg/L					
					Value NODI															
X 00556	Oil & Grease	1 - Effluent Gross	0	--	Sample									=	29.5	19 - mg/L	1	01/6M - Once Every 6 Months	GR - GRAE	
					Permit Req.								<=	15.0 DAILY MX	19 - mg/L					
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	170.0	=	170.0	07 - gal/d							0	01/90 - Quarterly	ES - ESTII	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	07 - gal/d										
					Value NODI															

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
00556	Oil & Grease	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

**Comments**  
 Please see attached non-compliance form.

**Attachments**

Name	Type	Size
TroopLOutfall0023Q2022.pdf	pdf	161839.0

**Report Last Saved By**  
 DEPT OF PUBLIC SAFETY  
 User: JDUPONT1980  
 Name: Jennifer Dupont  
 E-Mail: jdupont@eeusa.com  
 Date/Time: 2022-10-18 14:41 (Time Zone: -05:00)

**Report Last Signed By**  
 User: LSP\_TROOPL  
 Name: Louis Calato  
 E-Mail: louis.calato@la.gov  
 Date/Time: 2022-10-26 11:38 (Time Zone: -05:00)

# Submission Receipt

Submission Date: 10-26-2022

Submitter Name: Louis Calato

Submitter Telephone: (985) 893-6250

# Attachment 1



## Non-Compliance Report Form

**Facility Name:** Department of Public Safety State Police Troop L

**Facility Address:** (Quarterly) 2600 N. Causeway Blvd., Mandeville, LA 70471

**Person Reporting:** Lt. Louis Calato      **Title:** Lieutenant

**Phone Number:** 985-893-6239      **Parish:** St. Tammany

**LPDES Number:** LAG481115      **AI#:** 22734

**Receiving Waters:** From Bayou Tete L' Ours via local Drainage in (subsegment 040808) of the Lake Pontchartrain Basin.

(Refer to Subject Line on Permit Cover Letter)

Date of Non-Compliance	Parameter/Description (e.g. TSS, Overflow)	Outfall No./Location (e.g. 001, 123 Main St.)	Permit Limit	Reported Value
09-22-22	Oil and Grease	Outfall 002	15	29.5

**Cause of Violation(s):** The garage floors were cleaned shortly before testing. This may be the cause, or it is a possibility the separator tank is getting backed up.

**Corrective Action/Preventative Measures/Remediation:** A local contractor has been scheduled to perform an inspection and advise if the tank needs to be cleaned out, or serviced.

**Please submit as a PDF attachment in NetDMR or mail non-compliance reports to the following address:**  
**Office of Environmental Compliance**  
**Attn: Permit Compliance Unit**  
**P.O. Box 4312**  
**Baton Rouge, LA 70821-4312**