

KOSTMAYER CONSTRUCTION, LLC

1080 OLD SPANISH TRAIL, SUITE 14

SLIDELL, LA 70458

CONTRACTOR LICENSE #25747

OFFICE: (504) 837-3320

OR (985) 639-3575

FAX: (504) 837-8878

David Dammon
Dammon Engineering
554 Old Spanish Tr.
Slidell, Louisiana 70458

Subject: Kostmayer Construction, LLC/Hiram Investments,
USDA - APHIS Facility
924 Kenner Avenue, Kenner, LA
HVAC Submittal Approval

David,

This letter is to serve as notification that Kostmayer Construction, LLC/Hiram Investments, will assume all liability on the HVAC system for RTU #1 & RTU #4 in the above noted project above for the Johnson Controls Air Conditioning Units.

Kostmayer Construction, LLC/Hiram Investments, LLC recognizes that Dammon Engineering has raised the following issues with RTU #1 & RTU #4:

- Submitted unit may not be able to receive a MERV filter system.
- Submitted unit lacks a Moisture-Miser system.
- Submitted unit is a 240V

Despite, the issues noted above, Kostmayer Construction, LLC/Hiram Investments, wishes to push forward with the installation of these units. We ask that Dammon Engineering approve the submittals "As Submitted" which will allow the units to be ordered.

Thanks!



EQUAL OPPORTUNITY EMPLOYER