

[Ken Standing Office Bldg.]

Damon Eng. St. Tammany

US 190

Hydraulic Comments

New Office Building
Next to Banner Rd.

1-7-08

→ The structure under the proposed driveway is not on the drainage or site plan. Please add [24" x 50' CMP or 18" x 50' BCP (can be arched if needed/wanted)]

check → In the post-development calculations, 0.882 (60% total area) of green space seems very high from the layout. Please explain.

→ Where does the swale on the west ^{east} side of the property drain to? (every swale arrow is facing a different direction) Is this an existing swale or proposed swale? If existing, is this where the property currently drains?

If you have any questions please call or email me

Misty Evans

mistyevans@dotd.la.gov

985-375-0164