

STATE OF LOUISIANA
 DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
 OFFICE OF STATE FIRE MARSHAL CODE ENFORCEMENT AND BUILDING SAFETY
 8181 INDEPENDENCE BLVD., BATON ROUGE, LA 70806
 800-256-5452 225-925-4920 FAX: 225-925-4414
 www.lasfm.org

DATE OF APPLICATION: 4-27-11
SFM ARCHITECTURAL REVIEW NUMBER PO 394664
See Item 4a on instruction sheet

AUTOMATIC SPRINKLER SYSTEM MODIFICATION REQUEST FOR EXEMPTION

REVIEW FEE \$20.00

PROJECT INFORMATION:

PROJECT TITLE FROM APPLICATION (Name of Business) CHILDREN'S INTERNATIONAL MEDICAL GROUP		PROJECT FLOOR 1	
NAME OF BUILDING/SHOPPING CENTER		TOTAL NO OF FLOORS IN BUILDING 1	
PHYSICAL LOCATION OF PROJECT. <input checked="" type="checkbox"/> INSIDE CITY LIMITS <input type="checkbox"/> OUTSIDE CITY LIMITS	ADDRESS (Street/Suite) 8250 W JUDGE PEREZ DRIVE	EXEMPTION RESUBMITTAL? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO PREVIOUS REVIEW NUMBER: _____	
CITY CHALMETTE	PARISH ST BERNARD	STATE LA	ZIP CODE 70043

OWNER INFORMATION (or Professional of Record if applicable):

NAME ROBERT WILTSE, DAMMON ENGINEERING	SIGNATURE	LIC. NUMBER	PHONE 985-649-5832
MAILING ADDRESS 554 OLD SPANISH TRAIL		FAX 985-641-5950	
CITY SLIDELL	STATE LA	ZIP CODE 70458	
EMAIL ADDRESS Dammon Eng @ Bellsouth.net			

SPRINKLER SYSTEM INFORMATION

OCCUPANCY CLASS Business (NFPA 101 Chapter)		HAZARD CLASS LIGHT (Per NFPA 13)		PUMP INFORMATION		PLACARD INFORMATION		TOTAL NUMBER OF EXEMPTION SPRINKLERS 66	
SYSTEM TYPE <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY	DESIGN TYPE <input checked="" type="checkbox"/> HYDRAULIC <input type="checkbox"/> PIPE SCHEDULE	MAIN REDUC.VLV. SET _____psi PRESS REDUC.VLV. SET _____psi		PRESSURE (psi) _____ FLOW (psi) _____		_____ GSM/SF OVER _____ SF. WITH DEMAND OF _____ PSI AT _____ GPM AT:		AREA COVERED BY THIS EXEMPTION (sf)	
WATER SOURCE <input checked="" type="checkbox"/> MUNICIPAL <input type="checkbox"/> PRIVATE	WATER SUPPLY DATA	STATIC (PSI)	RESIDUAL (PSI)	FLOW (GPM)	TEST DATE	COST OF WORK TO BE DONE			

DESCRIPTION OF WORK
RELOCATE 18 AND LOWER 48 EXISTING HEADS FOR TENANT MODIFICATIONS. ALL HEADS TO BE REPLACED WITH QUICK RESPONSE HEADS.

SPRINKLER MFGR. VIKING	MODEL M QR	SIN NO.	TYPE PENDANT	TEMPERATURE 155*	ORIFICE SIZE 1/2 INCH
----------------------------------	----------------------	---------	------------------------	----------------------------	---------------------------------

EFFECT ON SYSTEM
 None.

SPRINKLER SYSTEM CONTRACTOR/ ENGINEER/ DESIGNER (not the POR)

NAME: Stephanie Enclade	EMPLOYEE STATE LA	PHONE (504) 362-0198
SIGNATURE 	LIC. NUMBER E 6181	FAX (504) 367-0216
FIRM NAME Jefferson Sprinkler Inc.		
FIRM ADDRESS PO Box 129, Gretna, La 70054		FIRM LICENSE NUMBER F 760
CONTACT PERSON Raymond J. Strohmeyer, Jr.		EMAIL ADDRESS raymonds@jeffersonsprinkler.com

REPLY FOR FIRE MARSHAL USE ONLY	PROJECT NO.
	REVIEWER
	DATE RECEIVED

DENIED - RESUBMIT
 ACCEPTED

CONTACT THE INDICATED DISTRICT OFFICE FOR FINAL INSPECTION

HEALTH CARE DIVISION

BATON ROUGE 800-256-5452

LAFAYETTE 800-554-0006

NEW ORLEANS 888-634-7689

SHREVEPORT 888-634-7689

THIS EXEMPTION REQUEST IS VALID FOR 180 DAYS FROM DATE OF RESPONSE. INSTALLATION