

DAMMON ENGINEERING, INC.

dammonengineering.com

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

May 22, 2007

Lanco Construction, Inc.
5816 Plauche Ct.
Jefferson, La. 70123

Attn: Ron Blair
Ref: Addendum to strapping

All foundation corners shall be strapped in each direction using Simpson straps #PHD2-SDS3 against double studs.

Thanks
Chuck Dammon
Dammon Engineering