

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

**INFORMATION REQUEST
NOT - FOR - PERMITTING**

KEVIN KINCHEN
DAMMON ENGINEERING, INC.
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0445596
LAQUINTA INN WEST MONROE
507 CONSTITUTION DR
WEST MONROE, LA 71292

NFPA 101, 2012
IBC, 2012 (CHAPTERS 9 & 10)

APARTMENT

Dear Applicant:

Additional information is required to perform a proper review. The project referenced above is being held pending submission of the following information:

NOTE: THE COMMENTS LISTED BELOW IDENTIFY APPARENT DEFICIENCIES DETECTED IN OUR REVIEW OF THE DOCUMENTS SUBMITTED.

1. **RS 40:1574 and/or RS 40:1730.39.A Additional drawings and/or specifications are required:**
Provide documents were clarify the U.L. listings of all rated construction. Varying sheets call for different U.L. listings for the same assemblies.

2. **NOTE: Please ENCLOSE A COPY OF THIS LETTER WITH FUTURE SUBMITTALS OR OTHER CORRESPONDENCE pertaining to this project.**

Due to the lack of information, the referenced project has NOT been reviewed. Please direct the requested information to my attention. Processing will continue upon receipt of the information requested above. Enclose a copy of this letter with future submittals and/or other correspondence pertaining to this project.

This project will be returned as "NOT IN COMPLIANCE" if the requested information is not received by this office within 21 days of the date of this letter, thereby requiring a RESUBMITTAL of the entire project along with a new completed application and appropriate review fee.

Apr 3, 2014
P0445596 - PAGE 1

CONSTRUCTION IS NOT AUTHORIZED until a satisfactory review has been performed and a formal review letter has been issued by this office.

REVIEWED BY:
DAVID JONES
ARCHITECT

NOTE: Please call the REVIEWER identified above if you have any questions regarding this review.
Do not call the Inspection Office until you are ready for inspection.

CC:

My Hospitality Hotels
Ouachita Parish Hwy. Dept.
Patrick Hemphill*
Todd Smith*
City Of West Monroe Bldg Official*
City Of West Monroe Bldg Official*
West Monroe Fire Department*