



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241



H. "Butch" Browning
FIRE MARSHAL

PLAN REVIEW APPLICATION

MUSA KANCAL ADVANCED SINTER METAL TECHNOLOGIES
2589 FRONT STREET
SLIDELL LA 70458

Project Number: **FA-19-005838**
Review Type: **Fire Alarm System**
Status: **Resubmittal Required**
Date Completed: **4/3/2019**
Code Edition:

DEFICIENCIES CITED ON THE PROJECT

In accordance with L.R.S. 40:1574 et seq., satisfactory compliance with the requirements of the laws, rules, regulations and codes of the state that are entrusted to the State Fire Marshal to uphold must be achieved before any work is performed. As such, a permit shall not be issued or construction or installation of the scope of work identified herein shall not commence until the Status of this review is "Released" and the requirements of other state and local entities have been satisfied.

Project Description: SEE THE ATTACHED SUBMITTAL PACKET FOR A DETAILED SCOPE OF WORK			
Project Name: ADVANCED SINTER METAL TECHNOLOGIES		Address: 2589 FRONT STREET, SLIDELL, LA 70458	
Funding Type: Private Project	Within City Limits? YES	Number of Stories:	High Rise Building:
Occupancy Separation Type:	Total Occupancy Square Feet: 22073	Project on which Floor(s): 1	Construction Type: II-B / II(000)
Additional Features (if applicable): Fire Alarm System			

Occupancy Type(s) and Square Feet		
Occupancy Type: Factory/Industrial	Square Feet: 22073	Details: TYPE OF FACTORY/INDUSTRIAL BUILDING: GROUP F-2 (LOW HAZARD)

Fire Alarm	
Is this System required by Code or by an Equivalency to Code?	Not Required
Is the system a new installation or a modification to an existing system?	N
System Type:	Remote Station


Device Type: Smoke Detector (Include Duct Detectors)	Number of Devices: 1
Panel	1

Are plans being submitted by OSFM Licensed Qualifier? Y		
OSFM Firm License Number: F122	OSFM Qualifier License Number: E721	Engineer License Number:

Individuals Involved in this Project		
Name: MUSA KANCAL	Role: Owner	Address: 2589 FRONT STREET, SLIDELL, LA 70458
MICHAEL JOSEPH LEJEUNE JR	Contractor	5221 W NAPOLEON AVENUE, METAIRIE, LA 70001

Deficiencies	
1	<p>NOTE: A RESUBMITTAL is required due to the following major deficiencies;</p> <ul style="list-style-type: none"> ~ Project description and scope indicate this is a new system with a new Fire Alarm Control Panel, which is separate and apart from the existing system panel in the adjacent building. ~ RESUBMIT the fire alarm system as a new required system. The fire alarm system is required per NFPA 101:40.3.4. Based upon information provided, the facility is classified as Industrial occupancy NFPA 101:40.1.2. The occupant load exceeds 100 persons. ~ The facility appears to be a change of occupancy classification from a prior Storage (Warehouse) occupancy to a new Industrial occupancy. Per Louisiana RS 37:155, the Louisiana State Board of Architectural Examiners requires projects of this occupancy classification that exceed 5,000 sq. ft. to have plans prepared, stamped and periodically supervised by an architect or civil engineer licensed in Louisiana. A separate submittal is required for the change of occupancy. SUBMIT for Architectural/Life Safety review.
2	<p>RS 40:1574 and/or RS 40:1730.39.A Additional information and/or action is required:</p> <ul style="list-style-type: none"> ~ Project description and scope appears to indicate a new system (separate and apart from the existing system) utilizing existing and new devices. The existing system control panel is located in and remains in the adjacent building and is not included in review of this system. ~ CLARIFY use and occupancy type of the facility. The project submittal data page indicates Factory (Industrial) Group F-1. The drawings indicate warehouse space (Storage occupancy). ~ IDENTIFY materials stored and/or fabricated.

The information submitted for review has been found to not be acceptable for permitting or construction. A resubmittal of a revised scope of work with completed application, revised drawings and specifications, and applicable review fee is required.

Review Completed By	
Signature: 	
Name: Kenneth Novak	Badge No.: 599

Distribution List		
Name	Firm Name	Role
ST TAMMANY FIRE PROTECTION DISTRICT NO 1*		Fire Prevention Bureau
CITY OF SLIDELL*		