



① ROOF POWER PLAN
3/16" = 1'-0"

KEYNOTES

26.435	STUB UP ELECTRICAL FOR RTU INSIDE UNIT CURB AND CONNECT CONNECTION WITH MECHANICAL EQUIPMENT CONNECTION SCHEDULE FOR RTU CONNECTION REQUIREMENTS. DISCONNECT AND GFCI RECEPTACLE ARE FACTORY INSTALLED SHALL BE FIELD WIRED.
26.438	EXHAUST FAN WITH FACTORY INSTALLED DISCONNECT. ELECTRICAL CONTRACTOR TO PROVIDE CIRCUITRY TO DISCONNECT.
26.440	REFER TO MANUFACTURER'S REQUIREMENTS FOR ICE MACHINE WIRING. CONNECT TO INTERIOR EQUIPMENT.
26.513	CIRCUIT EXHAUST HOOD FANS THROUGH HOOD PRE-WIRED PACKAGE. SEE HOOD CA SHEETS FOR DETAILS.
26.514	ELECTRICAL CONTRACTOR SHALL PROVIDE DISCONNECT SHOWN. PROVIDE CONDUIT FOR CONTROL WIRING TO INSIDE ELECTRICAL CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS.
26.515	MAU-1 ELECTRICAL CONTRACTOR SHALL PROVIDE AND INSTALL DISCONNECTS. PROVIDE CIRCUITRY TO DISCONNECTS. REFERENCE HOOD CA SHEETS FOR DETAILS.

STIPULATION FOR REUSE
 THE INFORMATION PREPARED FOR THIS PROJECT IS THE PROPERTY OF HARRISON FRENCH & ASSOCIATES, LTD. IT IS TO BE USED ONLY FOR THE PROJECT AND NOT TO BE REUSED FOR ANY OTHER PROJECT WITHOUT THE WRITTEN CONSENT OF HARRISON FRENCH & ASSOCIATES, LTD. ANY REUSE OF THIS INFORMATION FOR ANY OTHER PROJECT WITHOUT THE WRITTEN CONSENT OF HARRISON FRENCH & ASSOCIATES, LTD. IS STRICTLY PROHIBITED. HARRISON FRENCH & ASSOCIATES, LTD. SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THIS PROJECT. HARRISON FRENCH & ASSOCIATES, LTD. SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THIS PROJECT. HARRISON FRENCH & ASSOCIATES, LTD. SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FOR THIS PROJECT.

HFA
 HARRISON FRENCH & ASSOCIATES, LTD.
 1705 S. Walton Blvd., Suite 3
 Phenixville, Arkansas 72712
 1-479-273-7780
 www.hfa-ar.com

Loves'
 STORE NUMBER: 860
 I-59, EXIT 1
 NICHOLSON, MS 39466
 JOB NUMBER: 03-23-30009
 T1-90

ISSUE BLOCK

1	ADD 1	02/16/23
---	-------	----------

CHECKED BY: CAR
 DRAWN BY: SED
 DOCUMENT DATE: 2/17/2023
 PROTO: T1-90
 PHOTO CYCLE: 03 - 2022



ROOF POWER PLAN

SHEET: BGE411