



City of New Orleans

User ID: AEMUKAH

ACCELA AUTOMATIO

SmartManager	Application	Property	People	Fees	Cashier	Workflow	Document	Reports	Preference	Condition
--------------	-------------	----------	--------	------	---------	----------	----------	---------	------------	-----------

**Workflow History**

**Application:** 05COM-00395

**Submit**

**Application Type:** Permits / Commercial / Renovation (Structural) / NA

**Address:** 19401 CHEF MENTEUR, NEW ORLEANS, LA 70129

**Owner Name:** HALTER MARINE SER VICES INC

**Owner Address:** C/O RYAN & CO 3 GALLERIA TW, 13155 NOEL RD 12TH FL LB 72, DALLAS, TX 752405090

Task	Status	Status Date	Action By	Record Date/Time	Record By		
<u>Plan Review - Architectural</u>	Reviewed w/Comments	04/12/2005	ANTHONY O EMUKAH	2005-04-12 16:50:05	AEMUKAH	<b>Edit</b>	<b>Del</b>
<b>Comment:</b> 1. Drawings shall bear the live seal and signed statement of a Louisiana State registered architect or civil engineer as per Section 106 IBC as amended by the City of New Orleans. 2. Please refer to Section 416 IBC with reference to Spray rooms and verify compliance in its entirety. 3. Spray areas shall also comply with NFPA 33 Chapters 3: Construction of and Design of Spray Areas, Spray Rooms, and Spray Booths; Chapter 5: Ventilation and Chapter 7: Protection.							
<u>Plan Review - Electrical</u>	Reviewed w/Comments	04/11/2005	ED VISWANATHAN	2005-04-11 13:51:36	EVISWANATHAN	<b>Edit</b>	<b>Del</b>
<b>Comment:</b> 1. All wiring in Paint Booth area shall comply with NEC - 2002 article 516 2 All installed electrical wiring shall conform to the requirements of the International Building Code 2000 edition, as amended, the National Electrical Code [NFPA -70] and such other applicable safety codes as enforced by the Safety & Permits [ New Orleans Amendments to the International Building Code 2000 edition - 2735 Basic Standards-page 47 and Chapter 35 Reference Standards page 48 and Section 106 Article 106.1.1 ] 3 If total Electrical work done under this permit is less than \$15,000.00 dollars, then please provide an Electrical estimate of this job from an electrician who is licensed [EA- LICENSE ] with the City of New Orleans [New Orleans Amendments to the International Building Code 2000 edition Section 2705.1 PAGE 35 and and Section 106 Article 106.1.1] The estimate provided shall be written in the following format: a. Written on paper with the letter-head of the electrician or his electrical contracting company. b. Building Permit Number and the location address. c. Actual details of electrical work that will be done under this Building Permit. d. Estimated Bill shall consist of actual cost estimate of Labor and materials. e. Signature, License Number of the electrician, address, phone number and today's date. Electrician's estimate shall describe the actual work and not to refer to any plans, in case the plans do not bear wet seals and signed statement of a Louisiana Registered Electrical Engineer.							
<u>Application Acceptance</u>	Pending	04/07/2005	CYNTHIA CROSS	2005-04-07 11:09:20	CCROSS	<b>Edit</b>	<b>Del</b>
<b>Comment:</b> Default Status							
<u>Plan Review - Zoning</u>	Completed	04/07/2005	CYNTHIA CROSS	2005-04-07 11:14:27	CCROSS	<b>Edit</b>	<b>Del</b>
<b>Comment:</b> None							
<u>Application Acceptance</u>	Approved w/Plan Review	04/07/2005	CYNTHIA CROSS	2005-04-07 11:13:44	CCROSS	<b>Edit</b>	<b>Del</b>
<b>Comment:</b> Default Status							

v