

1880

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

AMENDED LETTER

ROBERT WILTSE
DAMMON ENGINEERING INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0344526
TEXTRON MARINE & LAND
2585 FRONT ST
SLIDELL, LA 70458-0000

NFPA 101, 2006

INDUSTRIAL

Dear Applicant:

This is to advise that the previous review letter dated 04/02/2008 for this project is hereby amended as follows:

1. **Disregard item no. 4 of original review letter for this project.**

The fire alarm visual notification in the warehouse is not required and the selective locations indicated in the original document are acceptable as proposed for identifying the location of exit doors from the large building.

2. **NOTE: The rest of the original review letter for this project shall remain applicable. Please enclose a copy of this letter with future submittals or other correspondence pertaining to this project.**

This review applies to the work indicated on the drawings or specifications.

This review shall in no way permit or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations in accordance with R.S. 40:1574.1(B).

The above amended review is valid if construction starts within 180 days from the above date of the original review letter.

Occupancy of the project will not be permitted until we receive the completed certificate and a satisfactory inspection of the completed construction has been made by this office.

To arrange for inspection of the project, please contact the District Office at the phone number below, two (2) to three (3) weeks in advance. Approved plans must be available on job site at time of inspection. Certificate of completion must be provided to inspecting Deputy for final inspection.

REVIEWED BY:
JAMES WAITE
ARCHITECT

CC:

Textron

Priority Systems, Inc

Property Insurance Association*

St Tammany Fire Protection District No 1*

City Of Slidell*

New Orleans District* 5042194600