



**DAMMON**  
ENGINEERING, INC.

554 Old Spanish Trail  
Slidell, LA 70458  
Phone: 985-649-5832

dammonengineering.com  
info@dammonengineering.com

## Manufactured Home Inspection

September 1, 2020

Seller: Angele Hepting  
39747 Hwy 1056  
Mt. Hermon, La. 70450

Purchaser: Devin Olman  
39733 Hwy 1056  
Mt. Hermon, La. 70450

RE: Manufactured Home – FHA Requirements

1. The foundation system is adequate for the soil conditions of the site as per HUD Handbook 7584, attachment B.
2. Tie downs are tied to screw anchors in the ground and meet the HUD/FHA requirement as installed by manufacturer.
3. Wheels and axles have been removed.
4. The tongue and trailer hitch have been removed.
5. The unit is permanently connected to the water and waste system.
6. Per HUD/FHA requirements, the crawlspace is enclosed with skirting with ventilation and access panels.
7. I certify that the foundation meets the requirements of FHA.
8. I certify that the foundation meets the requirements of the manufactured housing industry specification for foundations, HUD Handbook 7584, dated September 1996.
9. All handrails were found to be structurally sound, meeting the requirements for R311.5.3 Stairs and Treads of the IRC and R311.5.6.

Sincerely,

*Brian Mistich*

Brian A Mistich, P.E.  
LA License No. 0030187

