

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

554 Old Spanish Trail
Slidell, LA 70458

985-649-5832
FAX 985-641-5950

February 03, 2012

Paul Carroll
Parish Engineer
St. Tammany Parish

RE: Pool Installation
Chip & Wendy Englande
1038 Mariners Cove Blvd.
Slidell, La. 70458

Dear Mr. Carroll,

Per our review of the pool drawings provided Dammon Engineering from the owners, as the pool is designed it will not encroach on any setbacks or bulkheads per the layout. The pool is located 22' from the bulkhead and 12' from the dead men and should not pose any problems to the bulkhead.

Sincerely,

Chuck Dammon