



November 02, 2017

Mr. Zachary Smith
Department of Safety and Permits
City of New Orleans
1300 Perdido Street, Suite 7E06
New Orleans, LA 70112

RE: Permit No. 17-25080-RNVN
9561 Stroelitz
New Orleans, La.

Dear Mr. Smith.

Dammon Engineering was contacted to inspect the concrete piers/foundation located at the referenced location and requested that I provide you with the following affidavit.

It is my professional opinion that the foundation was constructed to meet the requirements of the 2012 IRC, and is structurally sufficient for the use intended. Each pier foundation consist of a 2x2 concrete pad with matted #5 rebar and one rebar up to frame enclosed in 8x16 CMU block with a PA 51strap for a total of eight piers. Skirting shall be installed to enclose the bottom.

The inspection was performed and this report is true and correct to the best of my knowledge and belief. This report shall serve as my affidavit that the foundation was erected according to provisions of Chapter 4 of the International Building Code, 2012 residential edition. I hereby assume full responsibility for the compliance with all provisions of the technical code for foundations and all other pertinent laws and ordinances, as pertains to the foundation of the structure.

This report does not cover any other aspects of the building such as framing, plumbing, electrical, gas, mechanical egress, general arrangement, site drainage, etc., and assumes that ground conditions are substantially the same as is under the residence.

Sincerely,

Brian A Mistich, P.E.
La. License No. 0030187