

ECO Builders Inc.

From: "ECO Builders Inc." <eco@ecobuildersinc.com>
To: "CHUCK DAMMON" <chuckdammon@yahoo.com>
Sent: Tuesday, June 12, 2007 12:37 PM
Subject: Audubon Building

Chuck,

I received a call yesterday from Ernie, a representative from DOTD, he has informed me that more information is needed for the approval on the permit. I have listed his request below. In addition, the permit application that was submitted has been revised and the new form can be found on their web site. Please see the link below.

- 1. New driveway permits needs to be submitted
- ✓2. Have driveway layout and drainage plan separate from each other (too much info. on one page)
- ✓3. Show drawings with exact radius on both sides
- ✓4. If open ditch, needs 5' of extended pipe on both sides of driveway (east & west) for drainage purpose;
- ✓5. Show distance of driveway with pipe data (how many feet, size of pipe)
- ✓6. Make sure you have enough pipe to cover the ditch (5' on each side)

Email for new, revised permit application:

http://www.dotd.louisiana.gov/highways/maintenance/maintmg/mgm_row_permits.asp

DOTD Contact:

Ernie @ 985-375-0130

If you have any question please contact Ernie at your convenience.

Sincerely,

Robin Marquez
Job Coordinator
E.C.O. Builders, Inc.
900 Old Spanish Trail
Slidell, LA 70458
(985) 645-9558 Office
(985) 645-9164 Fax

641-5950

sent out
6-18-07
jmw