



St. Tammany Fire Protection District #1 - Fire Prevention Bureau

1358 Corporate Square Slidell La.
70458
PO Box 1149

Phone: 985-646-4387 Fax: 985-646-4864

This inspection is intended for your safety and the safety of the citizens of Louisiana. Your cooperation is greatly appreciated.

STRUCTURE ID		SCHED. INSP. DATE	
OCCUPANCY	Floorworks & Blinds	INSP. TYPE	Inspection - New Construct
ADDRESS	1860 Shortcut Hwy		
CITY	Slidell	ACT INSPD. DATE	
STATE	LA	BEGIN TIME	9:00:37 am
ZIP	70458	INSPECTOR	Kreppin, Erik
OCCUPANCY TYPE	New Business Occupancies	RESCH. DATE	

<u>Code</u>	<u>Location</u>	<u>Description</u>
ADA 2010.5.502	Building	502 Parking Spaces.
Walk thru with contractor.		

Reviewed stamped plans. Separation between warehouse area and showroom has been constructed with 1 hr. separation. Plans show that is to be a 2 hr. wall. Provide documentation from SFM that only a 1 hr. is required, otherwise it will have to be built with a 2 hr. rating as per the stamped plans.

Provide handicapped ramp and parking with proper signage as discussed

502.2 Vehicle Spaces. Car parking spaces shall be 96 inches (2440 mm) wide minimum and van parking spaces shall be 132 inches (3350 mm) wide minimum, shall be marked to define the width, and shall have an adjacent access aisle complying with 502.3.

Signature and Title of person whom requirements were explained. <i>A. Honoré</i>	Signature of the Inspector. <i>Erik Kreppin</i>	Time Out
03/05/13		
<p>R.S. 40:1621 Whoever fails to comply with any order issued by the Fire Marshal or his authorized representative under any provision of Part III, Chapter 7, of Title 40 of the Louisiana Revised Statutes of 1950, R.S. 50:1569 expected, shall be fined not more than five hundred dollars or imprisoned, for not more than six months or both. Each day's violation of an order constitutes a separate offense and may be punished at the discretion of the court.</p>		