



August 15, 2013

Mr. Anouar Ait Iddir
1300 Perdido Street
City Hall-Room 7E06
New Orleans, LA 70112

RE: 15140 Intracoastal Dr.
Permit No. 13-08892-RNVN

Mr. Iddir

Please note the following responses to your letter dated July 19, 2013, copy attached.

Electrical:

- 2) You only submitted 1 copy of stamped set of plan.
Please find 2 sets of stamped Electrical Drawings
- 3) Sheet E1, Please clearly mark all the circuit designations for all light fixtures and receptacles.
E1 has been revised to reflect current circuit designations.
- 4) Sheet E1, please provide a detail drawing of the grounding system of the 75 kVA transformer as per NEC 2011 Art. 250.
E1 has been revised to include a detail of the grounding system for the 75kVA transformer.
- 5) Sheet E1, please label the specification of the feeder going from Fused Disconnect to MDP.
E1 has been revised to include the specification for the feeder.
- 6) Sheet E1, all panel schedules shall provide details of available short circuit currents at service and secondary panels.
Please find attached a calculation for Available Fault Current.

Sincerely,

David Dammon, VP
Dammon Engineering, Inc.