



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

September 1, 2016

Brian Mistich, P.E.  
Engineer  
554 Old Spanish Trail,  
Slidell, LA 70458

RE: Edenbourne Courts Apartment Class C Swimming Pool  
2<sup>nd</sup> Review  
New Orleans, LA

Dear Mr. Mistich,

Plans and specifications for the above named project have been reviewed. The plans are DISAPPROVED pending resolution of the following items which appear to be in conflict with applicable provisions of the State Sanitary Code, or upon which further information is needed.

1. Please clarify that the pools surface skimmer flow rates are within the manufacturers specifications. Model Aquatic Health code 2<sup>nd</sup> edition, 4.7.1.5.3, "The flow rate for the SKIMMERS shall comply with manufacturer data plates or NSF/ANSI 50 including Annex K."

Sincerely,

Brandon Comeaux, E.I.  
Region 1 Engineer Intern  
OPH – District I