

STATE OF LOUISIANA

Department of Public Safety and Corrections
 Office of State Fire Marshal Code Enforcement and Building Safety
 8181 Independence Boulevard
 Baton Rouge, Louisiana 70806
 225-925-4920

HENRY H. FRY
 DEPUTY ASSISTANT SECRETARY

NEW CONSTRUCTION

STEPHEN HILL
 BEATTY HILL GROUP
 426 NORTH FRONT ST
 STE 106
 MEMPHIS, TN 38103-0000

RE: P0322544
 HIGHLANDS OF GRAND ISLE, PHASE II,
 BUILDING 1
 3601 KALISTE SALOOM RD
 LAFAYETTE, LA 70501
 NFPA 101, 2003
 APARTMENT

Dear Applicant:

This is to advise that we have reviewed the drawings and specifications for the subject proposed construction and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

1. This project has been separated into 11 individual project numbers. This has been done so that each building may be completed, inspected and occupied individually. For reference sake plan see Sheet 33 of 67. The project numbers are:

P0322544 Building 1
 P0324237 Building 2
 P0324238 Building 3
 P0324239 Building 4
 P0324240 Building 5
 P0324241 Building 6
 P0324242 Building 7
 P0324243 Building 8
 P0324244 Building 9
 P0324245 Building 10
 P0324246 Club House

The review letter of P0322544 applies to all 10 apartment buildings on the site. The Club House has its own review letter.

NOTE: THE COMMENTS LISTED BELOW IDENTIFY APPARENT DEFICIENCIES DETECTED IN OUR REVIEW OF THE DOCUMENTS SUBMITTED.

Job # 8664

*UNDA
Bureau
225-4414*

January 31, 2008

State of Louisiana Fire Marshall's Office
8181 Independence Blvd.
Baton Rouge, LA 70806

Re: Grande Pointe 2 Apts.
3601 Kaliste Saloom Rd.
Lafayette, LA 70508

To Whom It May Concern:

Please find all information required for the application for the fire sprinkler permit enclosed.

We would like to request that a "go to work" permit be granted to Cherokee Piping Company for the fire sprinkler to be installed at the above mentioned property. Construction is moving very quickly and we need them to begin the installation immediately.

Please call Dammon Engineering office at 985-649-5832 or Cherokee Piping Co. at 713-856-5612, if you have any questions or need further information.

Sincerely,

Chuck Dammon
Dammon Engineering
1095 Florida Ave.
Slidell, LA 70458

2/8/2008

STATE OF LOUISIANA 061506
DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
OFFICE OF STATE FIRE MARSHAL CODE ENFORCEMENT AND BUILDING SAFETY
8181 INDEPENDENCE BLVD., BATON ROUGE, LA 70806
800-256-5452 225-925-4920 FAX: 225-925-4414
WEB SITE: www.dps.louisiana.gov/sfm

**SUGGESTED FORMAT FOR REQUEST LETTER TO BEGIN WORK ON THE SPRINKLER SYSTEM,
PRIOR TO REVIEW BY THIS OFFICE**

Please note the following suggested format, for professionals of record (or building owners when POR not required) requesting to have the sprinkler contractor "go to work" prior to review of the sprinkler system by this office. It is a policy of this office to review all plans submitted in as timely a manner possible. However, on occasions due to increased commerce within the state, this office will allow the commencement of the sprinkler system construction prior to our review, provided that the requested letter to "go to work" and the sprinkler submittal package (application, fee, system drawings, calculations, and system cut sheets) are received by this office.

Please contact Don Zeringue of this office, to confirm receipt and processing of your "go to work" request.

NOTE: Request may be sent by email, faxed or submitted with sprinkler package. Response will be sent by return fax if the fax number is provided.

SUGGESTED FORMAT FOR REQUEST LETTER:

Name of Professional of Record/POR or the Owner if no POR and address, telephone, fax, e-mail (on company letterhead if available)
License Number of POR
Date
TO Don Zeringue
Chief Architect
don.zeringue@dps.la.gov
Office of State Fire Marshal, Code Enforcement and Building Safety
8181 Independence Boulevard.
Baton Rouge, LA 70806

RE: Name of Project
Address of Project
Architectural Project Review Number P0* (for existing State Fire Marshal architectural review)
Sprinkler System Project Review Number P0* (if sent after project has been submitted and project number assigned. Not required if request is sent with package.)

As the Professional of Record (or Owner as applicable) for the above referenced project, I am requesting to be allowed to begin installation of the sprinkler system prior to completion of the plan review process. My reason(s) for this request is that (be specific here, explain the reasons for the time hereship involved that applies to this particular submittal.)

This project is a (indicate use of facility such as: existing restaurant, new restaurant currently under construction, new computer room, proposed auditorium, etc.).

I fully understand that the granting of this request by your office implies no approval of the work which we are requesting be allowed to commence. I further understand that the installation is being commenced entirely at the risk of the contractor and that any deficiencies will be corrected prior to use of the facility or equipment.

There will be no occupancy of the facility (or use of the equipment, appliances, computers, etc. - state specifics, as applicable) until such time as the review is complete and an inspection has been performed by the Office of State Fire Marshal.

Signed, Professional of Record (if required by law) otherwise Owner