



FLOOR PLAN
SCALE: 1/8" = 1'-0"

GA FILE NO. WP 1072 GENERIC

ONE LAYER 5/8" TYPE X GYPSUM WALLBOARD OR GYPSUM VENEER BASE APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 5-5/8" STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. AT FLOOR AND CEILING RUNNERS AND INTERMEDIATE STUDS.
JOINTS STAGGERED 24" ON EACH SIDE AND ON OPPOSITE SIDES. SOUND TESTED WITH 5-1/2" GLASS FIBER FRICTION FIT IN STUD SPACE. (NON-LOAD BEARING)



1 HOUR FIRE 45 TO 48 STC SOUND



THICKNESS: APPROX. HEIGHT: 6 PSF
FREE TEST: SEE WP 1200

(FM WP-45, 6-11-65);
OSU T-1710, 8-51;
ULC T47424, T47300, T47447,
8-12-91 ULC DESIGN (M415)
SOUND TEST: NRCC 816-NV, 2-3-81

GA FILE NO. WP 1521 GENERIC

GYPSUM WALLBOARD, STEEL STUDS

BASE LAYER 5/8" TYPE X GYPSUM WALLBOARD OR GYPSUM VENEER BASE APPLIED PARALLEL TO EACH SIDE OF 3 5/8" STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 24" O.C. FACE LAYER 1/2" TYPE X GYPSUM WALLBOARD OR GYPSUM VENEER BASE APPLIED PARALLEL TO EACH SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C.



2 HOUR FIRE 55 TO 59 STC SOUND



THICKNESS: 5 5/8"
LIMITING HEIGHT: REFER TO SECTION V
APPROX. WEIGHT: 9 PSF
SEE WP 1545
(UC, 9-7-64;
ULC 801499, 3-26-81
ULC DESIGN W414
NRCC 815-NV, 2-3-81

JOINTS STAGGERED 24" EACH LAYER AND SIDE. SOUND TESTED WITH 3 1/2" GLASS FIBER FRICTION FIT IN STUD SPACE (NLB).

SOUND TEST:

NEW ADA BATHROOMS N-3/0x6/8 DOORS W/CLOSURES

BOB THRISTRUP		DATE: 09-09-19	
FUTURE BUSINESS		CHECKED BY: BT	
550 GAUSE BLVD. SUITE 1 A SLIDELL, LA 70458		JOB No: 2019	
DRAWN BY: BT		DATE: 09-09-19	

A-1