



GENERAL ELECTRICAL NOTES:

- COORDINATE WITH OWNER, LOCATIONS OF ALL TELEPHONE AND ELECTRICAL SERVICE STUB-UPS INSIDE OF BUILDING.
- ALL CONDUIT SHALL BE MIN 1/2" DIAMETER UNLESS OTHERWISE NOTED.
- VERIFY EXACT LOCATION OF ALL OUTLETS AND FIELD COORDINATE PRIOR TO ANY WORK.
- PROVIDE JUNCTION BOX AND 3/4" CONDUIT WITH PULLWIRE STUBBED ABOVE ACCESSIBLE CEILING FOR ALL DATA AND COMMUNICATION DEVICE LOCATIONS. VERIFY EXACT LOCATIONS WITH SPECIFIC TENANTS PRIOR TO ROUGH-IN.
- LOW VOLTAGE WIRING FOR THERMOSTAT CONTROLS IS BY THE MECHANICAL CONTRACTOR. ELECTRICAL CONTRACTOR SHALL PROVIDE CONDUIT WITH PULL WIRES AND BACK BOXES AS NECESSARY FOR ROUGH-IN OF THERMOSTATS. COORDINATE LOCATIONS WITH MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.
- ADDITIONAL FIRE ALARM NOTIFICATION APPLIANCES WILL BE PROVIDED UNDER INDIVIDUAL TENANT FINISH CONTRACTS AS NECESSARY.
- DUCT SMOKE DETECTORS SHALL TRANSMIT A SUPERVISORY SIGNAL TO THE FIRE ALARM CONTROL PANEL AS REQUIRED BY LOCAL AHJ.

ELECTRICAL PLAN NOTES:

- LOW VOLTAGE DUCT SMOKE DETECTOR FURNISHED BY MECHANICAL CONTRACTOR. WIRE DUCT SMOKE DETECTOR FOR SHUT-DOWN OF RTU. PROVIDE SHUT-DOWN PER INDIVIDUAL TENANT CRITERIA. PROVIDE LOW VOLTAGE WIRING TO REMOTE INDICATOR LIGHTS, REMOTE TROUBLE LIGHTS, AND TEST/RE-SET STATIONS MOUNTED IN CEILING. IN UNFINISHED SPACES, TEMPORARILY MOUNT DEVICES AT ROOF JOISTS. LEAVE ENOUGH WIRE TO ALLOW PERMANENT MOUNTING IN CEILING BY TENANT.
- CEILING MOUNT RECEPTACLE NEAR WINDOWS FOR SHOW WINDOW LIGHTING/DISPLAY.
- PROVIDE FUSED DISCONNECT SWITCH, SIZE INDICATED ON PLANS.
- WIRE RECEPTACLE FURNISHED WITH UNIT.
- ELECTRIC WATER HEATER MOUNTED ABOVE CEILING. PROVIDE 30 AMP, TOGGLE SWITCH. REFER TO PLUMBING SHEETS.
- PROVIDE 1-1/4" CONDUIT WITH PULL STRING FROM PHONE BOARD LOCATION IN TENANT SPACE, ABOVE CEILING AND TERMINATED AT THE MAIN DEMARK BOARD IN SPRINKLER ROOM.
- JUNCTION BOX FOR STORE FRONT SIGNAGE. VERIFY LOCATION. PROVIDE 3/4" CONDUIT STUBBED THRU WALL AS REQUIRED. PROVIDE LOCAL DISCONNECT SWITCH AS REQUIRED BY NEC IF NOT FURNISHED WITH SIGN.
- HOMERUN CIRCUIT(S) THROUGH CONTACTOR CONTROLLED BY PHOTOCELL AND/OR TIME SWITCH. REFER TO CONTACTOR SCHEDULE FOR CONTROL SEQUENCE.
- FUTURE JUNCTION BOX FOR STORE SIGNAGE.
- PROVIDE WEATHERPROOF PUSHBUTTON OUTSIDE AT +48" A.F.F. WITH LOW VOLTAGE TRANSFORMER AND BELL/BUZZER INSIDE AS INDICATED ON PLANS. VERIFY INSTALLATION REQUIREMENTS WITH BELL/BUZZER MANUFACTURER AND TENANT. PROVIDE 4" DIAMETER SINGLE MAGNET VIBRATING TYPE 24VAC, 30VA, EDWARDS #55-605 BELL/BUZZER.
- TRENCHING REQUIRED TO ACCOMMODATE POWER AND TENANT'S DATA AND TELEPHONE LINES. PROVIDE (1) 2-1/2" AND (2) 3/4" PVC CONDUIT.
- PROVIDE 3/4" CONDUIT STUBBED-UP AT ENTRY DOORS AND RUN BELOW SLAB TO ABOVE CEILING FOR THEFT SECURITY EQUIPMENT.
- PROVIDE RECEPTACLE AND ISOLATED GROUND CIRCUIT IN WALL FOR CONNECTION OF SECURITY SYSTEM. VERIFY EXACT LOCATION WITH OWNER'S REPRESENTATIVE OR ARCHITECT.
- PROVIDE 6' COIL OF (2)#12, (1)#12, 1/2" FMS TERMINATE AT ONE END AT OUTLET BOX FOR FINAL CONNECTION BY CATO AND IT'S FASHION.
- RECEPTACLES FOR CATO AND IT'S FASHION SHALL BE MOUNTED 15" AFF TO CENTER OF RECEPTACLE.
- PROVIDE JUNCTION BOX MOUNTED ABOVE CEILING AND ISOLATED GROUND CIRCUIT FOR CONNECTION OF SECURITY SYSTEM. VERIFY EXACT LOCATION WITH OWNER'S REPRESENTATIVE OR ARCHITECT.
- JUNCTION BOX FOR STORE FRONT SIGNAGE. PROVIDE 3/4" CONDUIT STUBBED THRU WALL AS REQUIRED. PROVIDE LOCAL DISCONNECT SWITCH AS REQUIRED BY NEC IF NOT FURNISHED WITH SIGN. FINAL CONNECTION OF SIGN BY CONTRACTOR FOR CATO AND IT'S FASHION.
- TRENCHING REQUIRED TO ACCOMMODATE POWER AND TENANT'S DATA AND TELEPHONE LINES. PROVIDE (3) 1" PVC CONDUIT.
- PROVIDE 4" PVC CONDUIT WITH PULL CORD FOR TELEPHONE SERVICE. STUB UP AND CAP INSIDE AT DEMARK PHONE BOARD AND RUN TO POINT OF SERVICE AT PROPERTY LINE AS DIRECTED BY UTILITY.
- FIRE ALARM CONTROL PANEL. REFER TO SPECIFICATIONS SHEET EB FOR ADDITIONAL INFORMATION.
- PROVIDE 4" PVC CONDUIT WITH PULL CORD FOR CATV SERVICE. STUB UP AND CAP INSIDE AT NEAR PHONE BOARD AND RUN TO POINT OF SERVICE AT PROPERTY LINE AS DIRECTED BY UTILITY.
- PROVIDE 4'x4' PLYWOOD BACKBOARD FOR PHONE EQUIPMENT.

ALL DEVICES AND BRANCH CIRCUITING FOR THIS TENANT SPACE WILL BE PROVIDED AND INSTALLED BY TENANT.

CONDUIT AND WIRE FOR CIRCUITING TO RTU'S FOR THIS TENANT SPACE WILL BE PROVIDED AND INSTALLED BY TENANT.

PROVIDE (2) 3" EMPTY CONDUIT WITH PULL WIRE FOR TENANT PROVIDED PANELBOARD. VERIFY LOCATION OF STUB UP.

1 POWER FLOOR PLAN
SCALE: 1/8"=1'-0"

HENDERSON ENGINEERS
8325 LENEXA DRIVE
LENEXA, KS 66214
TEL 913.742.5000 FAX 913.742.5001
www.hel-eng.com
0750001106

REVISION #1	DATE	DESCRIPTION	BY

DDG DUPLANTIS DESIGN GROUP, PC
Respect. Integrity. Client Satisfaction. Excellence
THIBODAUX, LOUISIANA
MANDEVILLE, LOUISIANA
HOUSTON, TEXAS
Civil Engineering • Site Development • Land Planning • Public Works • Architecture
Phone: 985.447.7000
Fax: 985.447.7009
Houma, Louisiana 70301

STAMP
STATE OF LOUISIANA
ELECTRICAL ENGINEERING
COSTA S. GARNAM
REG. NO. 25258
EXPIRES 12/31/2008
PROFESSIONAL ENGINEER
8/28/09

PROPOSED RETAIL DEVELOPMENT
CITY OF BOULTE
ST. CHARLES PARISH, LOUISIANA
FOR THE SPECTRA GROUP, INC.
MEMPHIS, TENNESSEE

DRAWN
FLS
CHECKED
DWL
DATE
8/18/07
SCALE
AS NOTED ON DWG
PROJECT NO.
0750001106
FILE
0750001106E6.DWG
SHEET
E6