

PANELBOARD: TG
 BUS AMPS: 225A FAULT CURRENT: 11812 A EQUIPMENT GROUND BUS
 MAIN SIZE/TYP: MLO AIC RATING:22,000 FULLY RATED
 VOLTS/PHASE: 208Y/120V, 3PH, 4W SERVES: TENANT 'G'
 MOUNTING: SURFACE LOCATION: STOCKROOM, ROOM #702 SECTION: 1

CKT NO.	DESCRIPTION	VOLTAMPS/PHASE			WIRE NO.	BKR AMP	P	F	BKR WIRE NO.	VOLTAMPS/PHASE			DESCRIPTION	CKT NO.	
		A	B	C						A	B	C			
1	SALES AREA LIGHTING	1,008			12	20	1		35	8	2,568		2		
3	SALES AREA LIGHTING		1,007		12	20	1				2,568		4		
5	SPACE				12	20	1						6		
7	TIME SWITCH/CONTACTOR	200			12	20	1				2,568		8		
9	SPACE				11	20	12				360		10		
11	SPACE				11	20	12				250		12		
13	SHOW WINDOW RCPT	360			12	20	1						14		
15	SPACE				11	20	12				720		16		
17	SPACE				11	20	12				720		18		
19	SPACE				11	20	12				180		20		
21	SPACE				1	20	12				1,497		22		
23	SPACE				1	1							24		
25	SPACE				1	1							26		
27	SPACE				1	1							28		
29	SPACE				1	1							30		
31	SPACE				1	1							32		
33	SPACE				1	1							34		
35	SPACE				1	1							36		
37	SPACE				1	1							38		
39	SPACE				1	1							40		
41	SPACE				1	1							42		
SUBTOTAL		1,568	1,007								2,928	5,145	5,035		
TOTAL PHASE A - VA		4,496			CONN. VA	DF					LOAD	CONN. VA	DF		
TOTAL PHASE B - VA		6,152			CONN. VA	DF					REFRIGERATION	CONN. VA	DF		
TOTAL PHASE C - VA		5,035			CONN. VA	DF					HEATING	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					LIGHTING	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					RECEPTACLES	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					MOTORS	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					EXISTING	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					LARGE MOTOR	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					SHOW WINDOW	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					LITG TRACK	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF					MISC EQUIP	CONN. VA	DF		
TOTAL PNLBD - VA		15,683			CONN. VA	DF									

PANELBOARD NOTES
 EM - EMERG LTG / LOCKABLE TAB C# - VA LTG CONTACTOR #
 LTG TRACK - TRACK LENGTH
 SIGN/DISPLAY - SIGNAGE & DISPLAY CASE

PANELBOARD: TK
 BUS AMPS: 225A FAULT CURRENT: 10705 A EQUIPMENT GROUND BUS
 MAIN SIZE/TYP: MLO AIC RATING:22,000 FULLY RATED
 VOLTS/PHASE: 208Y/120V, 3PH, 4W SERVES: TENANT 'K'
 MOUNTING: SURFACE LOCATION: STOCKROOM, ROOM #1002 SECTION: 1

CKT NO.	DESCRIPTION	VOLTAMPS/PHASE			WIRE NO.	BKR AMP	P	F	BKR WIRE NO.	VOLTAMPS/PHASE			DESCRIPTION	CKT NO.	
		A	B	C						A	B	C			
1	STOCK / RESTRM/EMG LTG / FAN	1,078			12	20	1		60	6	5,520		2		
3	SALES AREA EMERGENCY/NL LTS		1,132		12	20	1				5,520		4		
5	SALES AREA LT				12	20	1				5,520		6		
7	SALES AREA LT				12	20	1				5,520		8		
9	SALES AREA LT				12	20	1				5,520		10		
11	SALES AREA LT				12	20	1				5,520		12		
13	SALES AREA LT				12	20	1				5,520		14		
15	SALES AREA LT				12	20	1				5,520		16		
17	FRONT SALES AREA LTS				12	20	1				360		18		
19	TRACK LTS				12	20	1				250		20		
21	TRACK LTS				12	20	1				1,500		22		
23	CEILING FANS BACK				12	20	1				200		24		
25	CEILING FANS FRONT				12	20	1				360		26		
27	CEILING FANS CASHWRAP				12	20	1				200		28		
29	TRACK LTS				12	20	1				200		30		
31	SPACE				12	20	1				1,200		32		
33	SHOW WINDOW RCPT				12	20	1				180		34		
35	SHOW WINDOW RCPT				12	20	1				180		36		
37	SPACE				1	1							38		
39	SPACE				1	1							40		
41	SPACE				1	1							42		
SUBTOTAL		6,154	6,304	6,398							13,260	11,980	12,680		
TOTAL PHASE A - VA		19,414			CONN. VA	DF					LOAD	CONN. VA	DF		
TOTAL PHASE B - VA		162			CONN. VA	DF					REFRIGERATION	CONN. VA	DF		
TOTAL PHASE C - VA		152			CONN. VA	DF					HEATING	CONN. VA	DF		
TOTAL PHASE C - VA		19,088			CONN. VA	DF					LIGHTING	CONN. VA	DF		
TOTAL PHASE C - VA		159			CONN. VA	DF					SIGN/DISPLAY	CONN. VA	DF		
TOTAL PHASE C - VA		56,787			CONN. VA	DF					KITCHEN	CONN. VA	DF		
TOTAL PHASE C - VA		158			CONN. VA	DF					EXISTING	CONN. VA	DF		
TOTAL PHASE C - VA		158			CONN. VA	DF					LARGE MOTOR	CONN. VA	DF		
TOTAL PHASE C - VA		158			CONN. VA	DF					SHOW WINDOW	CONN. VA	DF		
TOTAL PHASE C - VA		158			CONN. VA	DF					LITG TRACK	CONN. VA	DF		
TOTAL PHASE C - VA		158			CONN. VA	DF					MISC EQUIP	CONN. VA	DF		
TOTAL PHASE C - VA		158			CONN. VA	DF									

PANELBOARD NOTES
 EM - EMERG LTG / LOCKABLE TAB TS-TIMESWITCH
 C# - VA LTG CONTACTOR #
 LTG TRACK - TRACK LENGTH
 SIGN/DISPLAY - SIGNAGE & DISPLAY CASE

PANELBOARD: TH2
 BUS AMPS: 225A FAULT CURRENT: 13755 A EQUIPMENT GROUND BUS
 MAIN SIZE/TYP: MLO AIC RATING:22,000 FULLY RATED
 VOLTS/PHASE: 208Y/120V, 3PH, 4W SERVES: TENANT 'H'
 MOUNTING: SURFACE LOCATION: STOCKROOM, ROOM #8020 SECTION: 1

CKT NO.	DESCRIPTION	VOLTAMPS/PHASE			WIRE NO.	BKR AMP	P	F	BKR WIRE NO.	VOLTAMPS/PHASE			DESCRIPTION	CKT NO.	
		A	B	C						A	B	C			
1	SALES AREA LIGHTING-a	895			12	20	1		35	8	2,568		2		
3	SALES AREA EM LIGHTING-b		842		12	20	1				2,568		4		
5	SPACE				12	20	1				2,568		6		
7	SPACE				12	20	1						8		
9	SPACE				20	1	3						10		
11	TIME SWITCH/CONTACTOR	200			12	20	1						12		
13	SHOW WINDOW RCPTS	360			11	20	12						14		
15	SPACE				11	20	12				360		16		
17	SPACE				11	20	12				250		18		
19	SPACE				11	20	12				180		20		
21	SPACE				11	20	12				720		22		
23	SPACE				11	20	12				720		24		
25	SPACE				1	1							26		
27	SPACE				1	1							28		
29	SPACE				1	1					1,500		30		
31	SPACE				1	1							32		
33	SPACE				1	1							34		
35	SPACE				1	1							36		
37	SPACE				1	1							38		
39	SPACE				1	1							40		
41	SPACE				1	1							42		
SUBTOTAL		1,255	842	200							2,928	3,648	5,038		
TOTAL PHASE A - VA		4,183			CONN. VA	DF					LOAD	CONN. VA	DF		
TOTAL PHASE B - VA		4,490			CONN. VA	DF					REFRIGERATION	CONN. VA	DF		
TOTAL PHASE C - VA		37			CONN. VA	DF					HEATING	CONN. VA	DF		
TOTAL PHASE C - VA		5,238			CONN. VA	DF					LIGHTING	CONN. VA	DF		
TOTAL PHASE C - VA		44			CONN. VA	DF					RECEPTACLES	CONN. VA	DF		
TOTAL PHASE C - VA		13,911			CONN. VA	DF					MOTORS	CONN. VA	DF		
TOTAL PHASE C - VA		39			CONN. VA	DF					EXISTING	CONN. VA	DF		
TOTAL PHASE C - VA		39			CONN. VA	DF					LARGE MOTOR	CONN. VA	DF		
TOTAL PHASE C - VA		39			CONN. VA	DF					SHOW WINDOW	CONN. VA	DF		
TOTAL PHASE C - VA		39			CONN. VA	DF					LITG TRACK	CONN. VA	DF		
TOTAL PHASE C - VA		39			CONN. VA	DF					MISC EQUIP	CONN. VA	DF		
TOTAL PHASE C - VA		39			CONN. VA	DF									

PANELBOARD NOTES
 EM - EMERG LTG / LOCKABLE TAB C# - VA LTG CONTACTOR #
 LTG TRACK - TRACK LENGTH
 SIGN/DISPLAY - SIGNAGE & DISPLAY CASE

PANELBOARD: TH1
 BUS AMPS: 225A FAULT CURRENT: 13755 A EQUIPMENT GROUND BUS
 MAIN SIZE/TYP: MLO AIC RATING:22,000 FULLY RATED
 VOLTS/PHASE: 208Y/120V, 3PH, 4W SERVES: TENANT 'H'
 MOUNTING: SURFACE LOCATION: STOCKROOM, ROOM #8020 SECTION: 1

CKT NO.	DESCRIPTION	VOLTAMPS/PHASE			WIRE NO.	BKR AMP	P	F	BKR WIRE NO.	VOLTAMPS/PHASE			DESCRIPTION	CKT NO.
		A	B	C						A	B	C		
1	SALES AREA LIGHTING-a	895			12	20	1		35	8	2,568		2	
3	SALES AREA EM LIGHTING-b		842		12	20	1				2,568		4	
5	SPACE				12	20	1				2,568		6	
7	SPACE				12	20	1						8	
9	SPACE				20	1	3						10	
11	TIME SWITCH/CONTACTOR	200			12	20	1						12	
13	SHOW WINDOW RCPTS	360			12	20	1						14	
15	SPACE				11	20	12				360		16	
17	SPACE				11	20	12				250		18	
19	SPACE				11	20	12				180		20	
21	SPACE				11	20	12				720		22	
23	SPACE				11	20	12				720		24	
25	SPACE				1	1							26	
27	SPACE				1	1							28	
29	SPACE				1	1					1,500		30	
31	SPACE				1	1							32	
33	SPACE				1	1							34	
35	SPACE				1	1							36	
37	SPACE				1	1							38	
39	SPACE				1	1							40	
41	SPACE				1	1							42	
SUBTOTAL		1,255	842	200							2,928	3,648	5,038	
TOTAL PHASE A - VA		4,183			CONN. VA	DF					LOAD	CONN. VA	DF	
TOTAL PHASE B - VA		4,490			CONN. VA	DF					REFRIGERATION	CONN. VA	DF	
TOTAL PHASE C - VA		37												