



- HVAC PLAN NOTES:**
- ROUTE SUPPLY AND RETURN AIR DUCT UP AND TRANSITION TO FULL-SIZE CONNECTION AT ROOFTOP UNIT. INSTALL SMOKE DETECTOR(S) IN MAIN PLENUM DUCT(S) DOWN FROM UNIT.
 - ROUTE RETURN AIR DUCT DOWN TO 22x22 CRG(S) WITH 18\"/>

NOTE TO CONTRACTOR:

CONTRACTOR SHALL PERFORM TEST READINGS ON FANS, UNITS, COILS, ETC. AND ADJUST EQUIPMENT TO DELIVER SPECIFIED AMOUNTS OF AIR. AIR SHALL BE BALANCED TO WITHIN PLUS/MINUS 10% OF DESIGN REQUIREMENTS. ADJUST AIR DEVICES TO SUPPLY THE AMOUNT OF AIR SHOWN ON THE DRAWINGS. FURTHER ADJUSTMENTS SHALL BE MADE TO OBTAIN UNIFORM TEMPERATURE IN SPACES. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS.

1 HVAC FLOOR PLAN
SCALE: 1/8"=1'-0"

REVISION #	DATE	DESCRIPTION	BY
3/04/08			
3/27/08			
3/13/09			

DDG DUPLANTIS DESIGN GROUP, PC
 Respect • Integrity • Client Satisfaction • Excellence
 THIBODAUX, LOUISIANA
 Civil Engineering • Site Development • Land Planning • Public Works • Construction
 314 East Bayou Road
 Thibodaux, Louisiana 70301
 Phone: 985.447.0090
 Fax: 985.447.7009

STATE OF LOUISIANA
 BOARD OF PROFESSIONAL ENGINEERS
 DORIS E. HENDERSON
 LICENSE NO. 10757
 PROFESSIONAL ENGINEER
 IN
 MECHANICAL ENGINEERING
 3/12/09

PROPOSED RETAIL DEVELOPMENT
 CITY OF BOULTE
 ST. CHARLES PARISH, LOUISIANA
 FOR THE SPECTRA GROUP, INC.
 MEMPHIS, TENNESSEE

HENDERSON ENGINEERS
 8325 LEXENA DRIVE
 LEXENA, KS 66214
 TEL 913 742 5000 FAX 913 742 5001
 www.hel-eng.com
 075001106

DRAWN: BME
 CHECKED: KLB
 DATE: 8/13/07
 SCALE: AS NOTED ON DWG
 PROJECT NO.: 0750001106
 FILE: 0750001106MS.DWG
 SHEET: M3

GP:\Programs\Duplantis\075001106_Spectra Retail Center - Boulte - LA\000\Mech\075001106MS.dwg, Plot: 3/12/2009 4:01:18 PM, d:\myname\m001, 11