



Bobby Jindal
GOVERNOR

Bruce D. Greenstein
SECRETARY

State of Louisiana
Department of Health and Hospitals
Office of Public Health

November 24, 2010

Re: Marcos Pizza
532 Gause
Slidell, LA

Dear Sirs:

Plans and specifications for the above named project have been reviewed and found to be in substantial conformity with applicable provisions of the State Sanitary Code. This plan approval refers to sanitary features of the design of the floor plan only, and is not to be taken as an approval of structural details, except insofar as they may affect sanitation.

If a design error escapes our detection, that oversight shall not relieve you of the responsibility of complete compliance with the requirements of the State Sanitary Code.

This plan approval is automatically cancelled if construction of the project has not been started within two (2) years after the date of this letter.

Note: Approved with dumpster area hot/cold water and minimum 40 lbs grease interceptor at dumpster area

Sincerely,

A handwritten signature in cursive script that reads "Rose Linzell".

Rose Linzell
Sanitarian III