



# DAMMON

ENGINEERING, INC.

554 Old Spanish Trail  
Slidell, LA 70458  
Phone: 985-649-5832

dammonengineering.com  
info@dammonengineering.com

---

Christopher Brown, CBO, CFM  
Building Official / Floodplain Administrator  
City of Covington, LA  
317 N Jefferson Ave  
PO Box 778  
Covington, LA 70434

RE; Full Moon Bar & Grill  
1957 North Collins Blvd.  
Covington, La.

Mr. Brown,

Please accept this letter of notice that Dammon Engineering inspected the construction of the removal of the second floor and that all the structural columns were existing and only wrapped for cosmetics purposes.

The interior stair opening was closed in with wood studs to make a rated wall per the Fire Marshal requirements. The second floor wall that is exposed to the down stairs is wood frame constructed and rated per the fire marshal requirements.

The fur down over the bar is 2x4 wood frame and warped in sheetrock.

I hereby assume full responsibility for the compliance with all provisions of the technical code as it pertains to the structure.

Sincerely,

Brian Mistich, P.E.